

# Bottom Ash Transport Water Best Management Practice Plan

MERRIMACK STATION  
*Bow, New Hampshire*

Prepared for GSP Merrimack  
LLC File No. 2025.15  
October 2023

February 2025 Update



# TABLE OF CONTENTS

|   |  |
|---|--|
| INITIAL CERTIFICATION .....                           | 1  |
| ANNUAL RECERTIFICATION.....                           | 2  |
| Management Certification.....                         | 2  |
| Professional Engineer Annual Certification .....      | 2  |
| INTRODUCTION.....                                     | 4  |
| 1.0 GENERATING UNIT IDENTIFICATION .....              | 4  |
| 2.0 SYSTEM DESCRIPTION.....                           | 4  |
| 3.0 WATER BALANCE .....                               | 5  |
| 4.0 BATW SYSTEM MAINTENANCE AND INSPECTION .....      | 5  |
| 5.0 EVALUATION OF BATW ELIMINATION/MINIMIZATION ..... | 6  |
| 6.0 RECYCLE SYSTEM AND DISCHARGE MINIMIZATION.....    | 6  |
| 7.0 SCHEDULE FOR IMPLEMENTATION .....                 | 6  |
| 8.0 RECYCLE SYSTEM MAINTENANCE AND INSPECTION .....   | 6  |
| 9.0 FLOW MONITORING .....                             | 7  |
| APPENDICES  |  |
| Appendix A  | Limitations  |
| Appendix B  | Schematic of Water Flow  |
| Appendix C  | Inspection Reports and a Summary of Preventative Maintenance Performed |
| Appendix D  | Weekly Flow Measurements   |



**INITIAL CERTIFICATION**

**Management Certification**

GSP Merrimack LLC (GSP) is committed to working towards reducing bottom ash transport water (BATW) discharges from the Merrimack Station facility and will provide the manpower, equipment, and materials necessary to implement this BATW Best Management Practices (BMP) Plan. The undersigned authorized facility representative attests that:

- a) I have personally examined and am familiar with the included BATW BMP Plan;
- b) I believe that the information in the BATW BMP Plan and any supporting documentation used in the development of this plan is true, accurate, and complete; and
- c) The BATW BMP Plan, to the best of my knowledge and belief, meets the requirements of 40 CFR 423.

ELIZABETH H. TILLOTSON      Elizabeth H. Tillotson      October 31, 2023  
 Printed Name of Facility Representative      Signature      Date


**Professional Engineer Certification**

The BATW BMP Plan was prepared by Sanborn, Head & Associates, Inc. for the Merrimack Station facility located in Bow, New Hampshire. I, the undersigned Registered Professional Engineer, certify the following information in respect to the Merrimack Station BATW BMP Plan), subject to the assumptions and limitations contained within the BATW BMP Plan.

- a) I am a licensed professional engineer in the State of New Hampshire.
- b) I am familiar with the 40 CFR Part 423(k)(3) requirements for the BATW BMP Plan.
- c) I am familiar with the Merrimack Station BATW system;
- d) The BATW BMP Plan is included with this certification statement; and
- e) The BATW BMP Plan, to the best of my knowledge and belief, will be implemented by GSP if the MK1 Boiler and MK2 Boiler units are designated low utilization electric generating units (LUEGUs).

Harrison R. Roakes  
 Printed Name of Licensed Professional Engineer

[Signature]  
 Signature



15920      New Hampshire      October 31, 2023  
 License Number      Licensing State      Date

**ANNUAL RECERTIFICATION**

**Management Certification**

GSP Merrimack LLC (GSP) is committed to continuing to work towards reducing bottom ash transport water (BATW) discharges from the Merrimack Station facility and provide the manpower, equipment, and materials necessary to implement this BATW Best Management Practices (BMP) Plan. The undersigned authorized facility representative attests that:

- a) I have personally examined and am familiar with the included BATW BMP Plan;
- b) I believe that the information in the BATW BMP Plan and any supporting documentation used in the development of this plan is true, accurate, and complete;
- c) The BATW BMP Plan, to the best of my knowledge and belief, meets the requirements of 40 CFR 423; and
- d) The BATW BMP Plan is being implemented by GSP at Merrimack Station and the BMP Plan and corresponding flow records are being maintained at the facility.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

|   |                               |                    |
|---|-------------------------------|--------------------|
| <u>ELIZABETH H. TILLOTSON</u>           | <u>Elizabeth H. Tillotson</u> | <u>28 FEB 2025</u> |
| Printed Name of Facility Representative | Signature                     | Date               |

**Professional Engineer Annual Certification**

The BATW BMP Plan was prepared and updated, as necessary, by Sanborn, Head & Associates, Inc. for the Merrimack Station facility located in Bow, New Hampshire. I, the undersigned Registered Professional Engineer, certify the following information in respect to the Merrimack Station BATW BMP Plan), subject to the assumptions and limitations contained within the BATW BMP Plan.


- a) I am a licensed professional engineer in the State of New Hampshire.
- b) I am familiar with the 40 CFR Part 423.13(k)(3) requirements for the BATW BMP Plan.
- c) I am familiar with the Merrimack Station BATW system;
- d) The BATW BMP Plan is included with this annual certification statement;
- e) The BATW BMP Plan, to the best of my knowledge and belief, is being implemented by GSP;
- f) The following are also provided with the BATW BMP Plan included with this annual certification statement:
  - i. Any updates to the BMP Plan;
  - ii. An attachment of weekly flow measurements from the previous calendar year;



- iii. The average amount of recycled BATW in gallons per day; and
- iv. Copies of inspection reports and a summary of preventative maintenance performed on the system; and
- g) To the best of my knowledge and belief, the BMP Plan and corresponding flow records are being maintained at the Merrimack Station facility located in Bow, New Hampshire.

HARRISON R. ROAKES  
Printed Name of Licensed Professional Engineer

  
Signature



15920  
License Number

NEW HAMPSHIRE  
Licensing State

2/28/2025  
Date



## INTRODUCTION

This Bottom Ash Transport Water (BATW) System Best Management Practices (BMP) Plan is prepared to meet the requirements of the Final Steam Electric Reconsideration Rule 40 CFR Part 423.13(k)(3) for the Merrimack Station facility. Sanborn, Head & Associates, Inc. (Sanborn Head) prepared this BATW BMP Plan for GSP Merrimack LLC (GSP). This BATW BMP Plan and the services provided by Sanborn Head are subject to the Limitations provided in Appendix A.

This BATW BMP Plan is intended to be a working document. Therefore, certain aspects of the BATW BMP Plan require continued review, and action must be documented in support of the annual certification process. Key aspects of the BATW BMP Plan that GSP is responsible for implementing are highlighted below.

- Note and address any needed editorial updates to the BATW BMP Plan.
- Periodically review the feasibility of implementing new BMPs to include in this plan that have the potential to reduce BATW discharges at the facility.
- Investigate options to minimize slag sluice operations to reduce the volume of BATW discharges, such as optimizing intermittent operations to reduce sluice flows.
- Maintain records to document BATW flows.
- Maintain records to document the average amount of recycled BATW.
- Complete regular BATW maintenance and inspections, including preparation of inspection reports and summaries of preventative and corrective maintenance performed.

### 1.0 GENERATING UNIT IDENTIFICATION

The coal-fired generating units that contribute bottom ash (BA) to the BATW system are identified as MK1 Boiler and MK2 Boiler. This BMP Plan is prepared to meet the requirements for a BATW BMP Plan for the MK1 Boiler and MK2 Boiler units. The requirement to implement a BATW BMP Plan was included in the National Pollutant Discharge Elimination System (NPDES) Permit NH0001465 Permit Modification issued by the USEPA Region 1, dated March 20, 2024.

### 2.0 SYSTEM DESCRIPTION

A water flow diagram that includes the BATW system is included as Appendix B.

The existing BA transfer system consists of a wet slag tank for collection of BA at the boiler with wet sluice of BA to the slag settling area. Water from the Merrimack MK1 cooling water tunnel and Merrimack MK2 cooling water tunnel are used for the BATW that transports BA from the MK1 Boiler and MK2 Boiler slag tanks, respectively. Bottom ash and water are drawn from the MK1 Boiler and MK2 Boiler slag tanks using jet pumps and travel by sluice to the slag settling area. Slag is collected and stored for beneficial reuse and water from the slag settling area travels to the service water pond. MK1 Boiler and MK2 Boiler slag tank seal water (aka overflow water), which is generated during normal operations to maintain the slag tanks at full level, is sent to the service water pond without passing through the slag sluice settling area. This seal water (overflow water) does not transport or sluice bottom ash (slag).



Some water from the service water pond is pumped at the service water pump house to be recycled for use in the flue gas desulfurization (FGD) absorber. Most of the water drawn for the FGD absorber is removed from the system via evaporation (steam) while much smaller amounts are removed as a component of the gypsum produced, and the remainder is handled as blowdown in the wastewater treatment facilities.

In addition to the flows mentioned above, the service water pond also receives storm drain and yard drain water, boiler blowdown, returned service water, and water from Waste Treatment Plant #1 (NPDES Permit NH0001465).

The service water pond discharges via NPDES Permit NH0001465 Internal Outfall 003A to the cooling canal, (designated Waste Treatment Plant #2), for eventual discharge to the Merrimack River via Outfall 003.

### 3.0 WATER BALANCE

A diagram of the water balance is included as Appendix B, and tabulated values are provided below in Exhibit 1.

**Exhibit 1 - Summary of BATW System Additions and Removals**

| Type   | BATW System Component  | Normal Station On-Line Operation Flow |
|--|--|---------------------------------------|
| Water removed from the BA transport system   | Outfall: Outfall 003A to Waste Treatment Plant #2                | 5,330,000 GPD                         |
|  | Service Water Pump House (primarily for FGD absorber use)        | 1,100,000 GPD                         |
|  | Non-Contact Cooling Water  | 144,000 GPD                           |
|  | Evaporation from the BATW system (e.g., from service water pond) | 4,000 GPD                             |
|  | Entrained with removed bottom ash                                | Not quantified                        |
| Water entering or recycled to the BA transport system. There is no BATW recycled back to the system in lieu of makeup water. | MK1 Cooling Water Tunnel   | 2,000,000 GPD (intermittent)          |
|  | MK2 Cooling Water Tunnel   | 4,230,000 GPD                         |
|  | Service water pump house return                                  | 100,000 GPD                           |
|  | Non-Contact Cooling Water Return                                 | 144,000 GPD (intermittent)            |
|  | Boiler Blowdown + Seal Water (Overflows) & Storm Drains          | 11,000 GPD (intermittent)             |
|  | Waste Treatment Plant (#1)                                       | 81,515 GPD                            |
|  | Yard Drains  | 5,000 GPD (intermittent)              |

Note: As indicated above, some of the values represent typically intermittent flows. There is a non-zero balance of water removed and water added because of the intermittent flows.

### 4.0 BATW SYSTEM MAINTENANCE AND INSPECTION

A regular maintenance and inspection preventative maintenance management system is used to identify, repair, and replace equipment prior to failures. Preventative maintenance work orders are issued for timely upkeep of critical equipment and components.



The Operations Department does a walk-through at least daily to inspect the BATW system, including valves, pipe flanges and piping, to identify leaks, spills and other unintended bottom ash transport water escaping from the system. If needed, timely repairs are arranged.

Copies of inspection reports and a summary of preventative and corrective maintenance performed during the previous calendar year are included as Appendix C. Inspection reports are provided for days during which one or both MK units generated electricity.

## **5.0 EVALUATION OF BATW ELIMINATION/MINIMIZATION**

GSP completed an evaluation of costs and feasibility of full recycling of BATW to eliminate or minimize discharges. The evaluation recommendations were to install a remotely-located submerged flight conveyor (SFC) and associated infrastructure with an estimated cost of roughly \$7,000,000 (2021 dollars). Given the significant changes to Merrimack Station's operational profile in recent years (substantially reduced operations and thus BATW discharges), coupled with the likely permanent cessation of coal combustion at MK1 and MK2 in the foreseeable future, the installation of SFC technology is not economically viable.

## **6.0 RECYCLE SYSTEM AND DISCHARGE MINIMIZATION**

The following elements are included in the current BATW system for recycling and minimizing BATW discharge.

- BATW is recycled for use in the FGD scrubber.
- Investigate options to minimize slag sluice operations to reduce the volume of BATW discharges, such as optimizing intermittent operations to reduce sluice flows. The MK1 Boiler BATW sluice for emptying the slag tank is operated intermittently at a typically consistent flow, and minimizing the time that it is operating minimizes the BATW discharge.

Recycling BATW through the FGD scrubber reduces BATW discharges from the facility by over 1,000,000 GPD during normal station on-line operation. Reductions in BATW discharges achieved by other procedures implemented by GSP have not been quantified.

## **7.0 SCHEDULE FOR IMPLEMENTATION**

No changes to the existing BATW system are planned. The BMPs outlined in this plan represent the BATW discharge control measures that GSP determined are technically available and economically achievable for the Merrimack Station facility at this time. Options for BATW elimination or minimization, and the feasibility of such options, shall periodically be reassessed.

## **8.0 RECYCLE SYSTEM MAINTENANCE AND INSPECTION**

A regular maintenance and inspection preventative maintenance management system for the FGD system is used to identify, repair, and replace equipment prior to failures. Preventative maintenance work orders are issued for timely upkeep of critical equipment and components.

While operating, the Operations Department does a routine walk-through to inspect the FGD system. If needed, timely repairs are arranged.



## 9.0 FLOW MONITORING

Measurements associated with the flow monitoring, described below in Exhibit 2, are to be recorded on at least a weekly basis and kept in the BATW system maintenance and operation file.

**Exhibit 2 - Summary of BATW System Additions and Removals**

| BATW System Component   | Weekly Monitoring Method   | During Normal Station On-line Operation |               |
|---|--|---|---------------|
|   |  | Flow Type                               | Typical Flow  |
| MK1 BATW added to the BATW system, including the BATW slag sluice | Record start and stop times of water being added from the MK1 cooling water tunnel to the MK1 sluice system while the boiler is running. Sum the total run time of the MK1 sluice water addition and multiple by the typical operational flow rate to obtain the weekly flow volume.<br><br>There may be MK1 sluice water running while the boiler is not firing, but this water is not included as BATW given bottom ash is not generated during that time. | Intermittent                            | 2,000,000 GPD |
| MK2 BATW added to the BATW system, including the BATW slag sluice | Record start and stop times of water being added from the MK2 cooling water tunnel to the MK2 sluice system while the boiler is running. Sum the total run time of the MK2 sluice water addition and multiple by the typical operational flow rate to obtain the weekly flow volume.<br><br>There may be MK2 sluice water running while the boiler is not firing, but this water is not included as BATW given bottom ash is not generated during that time. | Continuous                              | 4,230,000 GPD |
| Total BATW discharged   | Continuous flow monitoring data are collected at Internal Outfall 003A.  | Continuous                              | 5,330,000 GPD |
| BATW recycled to the FGD absorber                                 | Operational or flow data will be collected to establish flows at the FGD absorber.   | Continuous                              | 1,100,000 GPD |

Note: As indicated above, some of the values represent typically intermittent flows. There is a non-zero balance of water removed and water added because of the intermittent flows.

Weekly BATW flow measurements from the previous calendar year and the average amount of recycled BATW are provided in Appendix D.



# **Appendix A Limitations**

## **APPENDIX A**


### **LIMITATIONS**

1. The observations described in this report were made under the conditions stated herein. The conclusions presented in this report were based solely upon the services described herein, and not on scientific tasks or procedures beyond the scope of described services or the time and budgetary constraints imposed by the Client.
2. In preparing this report, Sanborn Head has relied on certain information provided by other parties referenced herein. Detailed evaluations of this information to verify its validity was not conducted.
3. Should additional information on relevant conditions at the site which is not contained in the report be obtained, such information should be brought to Sanborn Head's attention. We will evaluate such information and, on the basis of our evaluation, may modify the conclusions stated in this report.
4. This report was prepared for the exclusive use of GSP Merrimack LLC (GSP) for specific application for 40 CFR Part 423(k)(3) compliance for GSP's Merrimack Station bottom ash transport water system for MK1 Boiler and MK2 Boiler electric generating units in Bow, New Hampshire, and was prepared in accordance with generally-accepted environmental engineering practices. No warranty, express or implied, is made.

# **Appendix B**

## **Schematic of Water Flow**





**Notes**

1. The Schematic of Water Flow for the Bottom Ash Transport Water Best Management Practice Plan was adapted from a drawing titled "Schematic of Water Flow, Merrimack Station", prepared by Granite Shore Power, dated February 20, 2023, with updates through January 17, 2024. Continuous flows are generally based on full load operation.
2. Evaporation rates were based on annual evaporation rate measured at Massabesic Lake, Manchester, New Hampshire, from Technical Paper No. 13: Mean Monthly and Annual Evaporation From Free Water Surface for the United States, Alaska, Hawaii, and West Indies, prepared by the U.S. Department of Commerce, dated July 1950. Reported monthly evaporation rates were greatest in June, July, and August.

**Legend**

- MGD Million Gallons Per Day
- GPD Gallons Per Day
- - - Intermittent flow
- Continuous Flow During Normal Station On Line Operation

Drawn By: D. Dombrowsky  
 Designed By: H. Roakes  
 Reviewed By: J. Scott  
 Project No: 2025.15  
 Date: July 2024

Not To Scale



**Appendix B**

**Schematic of Water Flow**

Bottom Ash Transport Water Best Management Practice Plan

Merrimack Station  
 Bow, New Hampshire

**Appendix C**  
**Inspection Reports and**  
**Preventative Maintenance**

Date: 01-19-2024

Shift: D

Name: Shawn Ball

Unit 1

|  |               |
|--|---------------|
| #2 Oil @ Midnight, Ignition Oil Tank / Yard Service Tank   | — / —         |
| 1B BFP Lube Oil Pressure   | 15 PSI        |
| 1B BFP Coupling Oil Temperature / Pressure   | 98 / 100 PSI  |
| 1A BFP Lube Oil Pressure   | 15 PSI        |
| 1A BFP Coupling Oil Temperature / Pressure   | 100 / 8 PSI   |
| 1A BFP Motor Bearing Lube Oil Pressure   | 12 PSI        |
| Cooling Water Heat Exchanger Inlet Temperature   | 62°           |
| Cooling Water Heat Exchanger Outlet Temperature  | 50°           |
| Cooling Water Heat Exchanger Discharge Pressure  | 75°           |
| Cooling Water Pump Discharge Pressure / Pumps in service   | 80 / 1 A+B    |
| Seal Oil Temperature   | 99.27         |
| Hydrogen Gas Pressure  | 28.1 PSI      |
| Hydrogen Fan Pressure  | 3.77          |
| Hydrogen Purity  | 99.4          |
| Hydrogen Temperature @ TCV   | 43°           |
| Hydrogen Dryer Dew Point   | -116.4°       |
| Condenser Inlet Temperature  | 39°           |
| Condenser Outlet Temperature North / South   | 70° / 70°     |
| Condenser Inlet Pressure North / South   | 4 PSI / 4 PSI |
| Gland Seal Steam Exhauster Vacuum "H2O   | 29.0          |
| Low Level Make Up Valve Opening  | 0             |
| Condensate Pump Discharge Pressure   | 200 PSI       |
| Turbine Oil Inlet Temperature  | 130°          |
| Turbine Oil Outlet Temperature   | 100°          |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 1.6 PSI       |
| Turbine Oil Vapor Extractor De-mister Pressure "H2O  | 2.5 PSI       |
| Slag Tank Pumps Elliot Strainer Differential   | 2             |
| Precipitator Flyash Hopper(s) Alarms in By-pass  | 2             |
| Flyash Blower Discharge Pressure   | 2.8           |
| Precipitator Flyash Hopper(s) in bypass  | 4             |
| Supplemental Flyash Hopper(s) in bypass  | 0             |
| River Level  | 192"          |
| Main Fire Pump Discharge Pressure  | 150 PSI       |
| Auxiliary Generator Coolant Temperature  | 109           |
| Auxiliary Generator Battery Voltage  | 26V           |
| Kaydon System Pressure / Water Meter Reading   | 0 / 32671     |
| All slag sluice handling equipment for MK1 has been inspected for proper operation and discrepancies have been reported. | OK            |
| Portable demin through put flow meter reading  | 0             |
| Comments:  |               |

TRANSFORMERS

|       | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS |
|-------|----------|----------|-----------|----------|----------|
| T 12  | 87       |          |           |          |          |
| RT 1  |          | 25       | —         | 0        |          |
| CMT 7 |          | 25       | —         | 0        |          |
| MT 1  |          | 40       | +         | 4        | 700      |

Note: When N2 bottle is 300 psi or lower, notify WFO.

Date: 1-19-24

Shift: \_\_\_\_\_

Name: \_\_\_\_\_

Unit 2

|  |                                  |
|--|----------------------------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 100 / 2B                         |
| Heat Exchanger Parallel Operation North and South  |                                  |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 80 / 80                          |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | <del>80</del> / <del>80</del> 80 |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | -2 / -5                          |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 0 / 9                            |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 71 / 60                          |
| 2B DA Pump Discharge Pressure  | 350                              |
| 2B DA Pump Bearing Lube Oil Pressure   | 3                                |
| 2A DA Pump Discharge Pressure  | 380                              |
| 2A DA Pump Bearing Lube Oil Pressure   | 2.5                              |
| MBFP/SUBFP Gland Water Pressure  | 260                              |
| Coupling Oil Pump Discharge Pressure   | 160                              |
| Coupling Oil Pump Suction Pressure   | 10                               |
| Coupling Oil Temperature   | 110                              |
| Turbine Oil Temperature  | 110                              |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 3.2                              |
| Condenser Inlet Temperature  | 35                               |
| Condenser Outlet Temperature East / West   | 90 / 90                          |
| Condenser Inlet Pressure East / West   | 4 / 5                            |
| Air Side/Gas Side Seal Oil Temperature   | 105 / 110                        |
| Hydrogen Dew Point / Hydrogen Purity   | -112 / 99.7                      |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.6 / 76                        |
| SBAC Cooling Water Supply Pressure   | 50 PSI                           |
| SBAC Discharge Air Pressure  | 194.7                            |
| SBAC Fourth Stage Inlet Temperature  | 77                               |
| SBAC Evacuator Vacuum "H2O   | 30.76                            |
| SBAC Oil Temperature   | 117°                             |
| SBAC Lube Oil Pressure   | 26 PSI                           |
| Flyash Blower Pressure North/South   | 4.1 / 7.1                        |
| Precipitator Flyash hopper(s) alarms in By-pass  | 6                                |
| Precipitator Flyash hopper(s) in By-pass   | 6                                |
| Supplemental Precip Flyash Blower Discharge Pressure   | 3.1                              |
| Supplemental Precip Flyash Hopper(s) in By-pass  | 1                                |
| Scr/Eco Flyash Blower Pressure   | <del>_____</del>                 |
| Scr or Eco Flyash system in Bypass   | <del>_____</del>                 |
| Hypo Tank Level  | —                                |
| Kaydon System Pressure / Water Meter Reading   | 0 / 4175                         |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ok                               |
| Comments:  |                                  |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 41       |          |           |          |          |        |
| T24 | 57       |          |           |          |          |        |
| ST2 | 40       | 410      | —         | 0        |          |        |
| RT2 | X1- 40   | 27       | —         | 0        | 1500     | —      |
|     | X2- 40   |          |           |          |          |        |
| MT2 | 70       | 100      | +         | 5        | 1400     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.



Date: 01-20-24

Shift: Day

Name: Shan Ball

Unit 2

|  |                 |
|--|-----------------|
| ✓ Cooling Water Pump Discharge Pressure / Pumps in service   | 60 PSI / 2B     |
| Heat Exchanger Parallel Operation North and South  |                 |
| ✓ Cooling Water Heat Exchanger Inlet Temperature North / South   | 80° / 80°       |
| ✓ Cooling Water Heat Exchanger Outlet Temperature North / South  | 80° / 80°       |
| ✓ Cooling Water Heat Exchanger Discharge Pressure North / South  | -2 psi / -5 psi |
| ✓ Air In-leakage @ 2A / 2B Vacuum Pumps  | 5 / 15          |
| ✓ Seal Water Temp @ 2A and 2B Vacuum Pumps   | 70 / 60         |
| ✓ 2B DA Pump Discharge Pressure  | 350 PSI         |
| ✓ 2B DA Pump Bearing Lube Oil Pressure   | 40 PSI 3PSI     |
| ✓ 2A DA Pump Discharge Pressure  | 25 PSI 400 PSI  |
| ✓ 2A DA Pump Bearing Lube Oil Pressure   | 30 PSI 2.5 PSI  |
| ✓ MBFP/SUBFP Gland Water Pressure  | 250 PSI         |
| ✓ Coupling Oil Pump Discharge Pressure   | 160 PSI         |
| ✓ Coupling Oil Pump Suction Pressure   | 10 PSI          |
| ✓ Coupling Oil Temperature   | 110° Degrees    |
| ✓ Turbine Oil Temperature  | 110° Degrees    |
| ✓ Turbine Oil Vapor Extractor Vacuum "H2O"   | 2               |
| ✓ Condenser Inlet Temperature  | 38°             |
| ✓ Condenser Outlet Temperature East / West   | 31° / 30°       |
| ✓ Condenser Inlet Pressure East / West   | 4 PSI / 5 PSI   |
| ✓ Air Side/Gas Side Seal Oil Temperature   | 105° / 107°     |
| ✓ Hydrogen Dew Point / Hydrogen Purity   | -125.7 / 99.5   |
| ✓ Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.4 / 76.7     |
| ✓ SBAC Cooling Water Supply Pressure   | 180.6 psi       |
| ✓ SBAC Discharge Air Pressure  | 191.8 psi       |
| ✓ SBAC Fourth Stage Inlet Temperature  | 75°             |
| ✓ SBAC Evacuator Vacuum "H2O"  | 33.07           |
| ✓ SBAC Oil Temperature   | 116°            |
| ✓ SBAC Lube Oil Pressure   | 121°            |
| ✓ Flyash Blower Pressure North/South   | 9.2 / 9.2       |
| ✓ Precipitator Flyash hopper(s) alarms in By-pass  | 0               |
| ✓ Precipitator Flyash hopper(s) in By-pass   | 6               |
| ✓ Supplemental Precip Flyash Blower Discharge Pressure   | 3               |
| ✓ Supplemental Precip Flyash Hopper(s) in By-pass  | 1               |
| ✓ Scr/Eco Flyash Blower Pressure   | —               |
| ✓ Scr or Eco Flyash system in Bypass   | —               |
| ✓ Hypo Tank Level  | —               |
| ✓ Kaydon System Pressure / Water Meter Reading   | 0 / 4175        |
| ✓ All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | OKay            |
| Comments:  |                 |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 47       |          |           |          |          |        |
| T24 | 57       |          |           |          |          |        |
| ST2 | 40       | 40       | —         | 0        |          |        |
| RT2 | X1- 40   | 35       | —         | 0        | 1500     | —      |
|     | X2- 40   |          |           |          |          |        |
| MT2 | 60       | 50       | +         | 5        | 180      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

Date: 01-20-24

Shift: Day

Name: Shan Ball



Unit 2

|  |                           |
|--|---------------------------|
| ✓ Cooling Water Pump Discharge Pressure / Pumps in service   | 60PSI 2B                  |
| ✓ Heat Exchanger Parallel Operation North and South  |                           |
| ✓ Cooling Water Heat Exchanger Inlet Temperature North / South   | 80° / 80°                 |
| ✓ Cooling Water Heat Exchanger Outlet Temperature North / South  | 80° / 80°                 |
| ✓ Cooling Water Heat Exchanger Discharge Pressure North / South  | -2 PSI / -5 PSI           |
| ✓ Air In-leakage @ 2A / 2B Vacuum Pumps  | 5 / 15                    |
| ✓ Seal Water Temp @ 2A and 2B Vacuum Pumps   | 70 / 60                   |
| ✓ 2B DA Pump Discharge Pressure  | 350 PSI                   |
| ✓ 2B DA Pump Bearing Lube Oil Pressure   | <del>40 PSI</del> 3 PSI   |
| ✓ 2A DA Pump Discharge Pressure  | <del>25 PSI</del> 400 PSI |
| ✓ 2A DA Pump Bearing Lube Oil Pressure   | <del>30 PSI</del> 2.5 PSI |
| ✓ MBFP/SUBFP Gland Water Pressure  | 250 PSI                   |
| ✓ Coupling Oil Pump Discharge Pressure   | 160 PSI                   |
| ✓ Coupling Oil Pump Suction Pressure   | 10 PSI                    |
| ✓ Coupling Oil Temperature   | 110° Degrees              |
| ✓ Turbine Oil Temperature  | 110° Degrees              |
| ✓ Turbine Oil Vapor Extractor Vacuum "H2O"   | 2                         |
| ✓ Condenser Inlet Temperature  | 38°                       |
| ✓ Condenser Outlet Temperature East / West   | 80°                       |
| ✓ Condenser Inlet Pressure East / West   | 4 PSI / 5 PSI             |
| ✓ Air Side/Gas Side Seal Oil Temperature   | 105° / 107°               |
| ✓ Hydrogen Dew Point / Hydrogen Purity   | -125.7 / 99.5             |
| ✓ Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.4 / 70.7               |
| ✓ SBAC Cooling Water Supply Pressure   | 180.10 psi                |
| ✓ SBAC Discharge Air Pressure  | 191.8 psi                 |
| ✓ SBAC Fourth Stage Inlet Temperature  | 75°                       |
| ✓ SBAC Evacuator Vacuum "H2O"  | 33.07                     |
| ✓ SBAC Oil Temperature   | 116°                      |
| ✓ SBAC Lube Oil Pressure   | 121°                      |
| ✓ Flyash Blower Pressure North/South   | 4.2 / 8.2                 |
| ✓ Precipitator Flyash hopper(s) alarms in By-pass  | 0                         |
| ✓ Precipitator Flyash hopper(s) in By-pass   | 6                         |
| ✓ Supplemental Precip Flyash Blower Discharge Pressure   | 3                         |
| ✓ Supplemental Precip Flyash Hopper(s) in By-pass  | 1                         |
| ✓ Scr/Eco Flyash Blower Pressure   | —                         |
| ✓ Scr or Eco Flyash system in Bypass   | —                         |
| ✓ Hypo Tank Level  | —                         |
| ✓ Kaydon System Pressure / Water Meter Reading   | 0 / <del>4175</del>       |
| ✓ All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | OKay                      |
| Comments:  |                           |

TRANSFORMERS

|     | WDG TEMP         | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|------------------|----------|-----------|----------|----------|--------|
| 2TX | 47               |          |           |          |          |        |
| T24 | 57               |          |           |          |          |        |
| ST2 | 40               | 40       | —         | 0        |          |        |
| RT2 | X1- 40<br>X2- 40 | 35       | —         | 0        | 1500     | —      |
| MT2 | 60               | 50       | +         | 5        | 1800     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.



Date: 3-8-24

Shift: D

Name: AP

Unit 2

|  |               |
|--|---------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 2A 160        |
| Heat Exchanger Parallel Operation North and South  |               |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 42 144        |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 44 144        |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55 158        |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 0 1 0         |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 45 1 4.3      |
| 2B DA Pump Discharge Pressure  | 0             |
| 2B DA Pump Bearing Lube Oil Pressure   | 4             |
| 2A DA Pump Discharge Pressure  | 0             |
| 2A DA Pump Bearing Lube Oil Pressure   | 3.5           |
| MBFP/SUBFP Gland Water Pressure  | 0             |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 1130       |
| Coupling Oil Temperature   | 75            |
| Turbine Oil Temperature  | 74            |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 4.3           |
| Condenser Inlet Temperature  | 48            |
| Condenser Outlet Temperature East / West   | 48 48         |
| Condenser Inlet Pressure East / West   | 0 1 0         |
| Air Side/Gas Side Seal Oil Temperature   | 73 175        |
| Hydrogen Dew Point / Hydrogen Purity   | -88.8 1 / 100 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 39.6 1 0.4    |
| Flyash Blower Pressure North/South   | 0 1 0         |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | All           |
| Supplemental Precip Flyash Blower Discharge Pressure   | 0             |
| Supplemental Precip Flyash Hoppers in Bypass   | All           |
| Kaydon System Pressure / Water Meter Reading   | 5 14175.5     |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ok            |
| TA-6040 Discharge pressure/Oil temperature   | 1.4 1 91      |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 46       |          |           |          |          |        |
| T24 | 66       |          |           |          |          |        |
| ST2 | 35       | 35       | -         | 0.5      |          |        |
| RT2 | X1- 8    | 5        | -         | 1        | 1900     |        |
|     | X2- 8    |          |           |          |          |        |
| MT2 | 10       | 10       | -         | 1        | 1700     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |      |
|---|---|----|------|
| Circulators in operation  | 2A  | 2B | Both |
| Screen house Recirc valve position  |   | 25 | %    |
| Forebay Frozen?   | YES   | NO |      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |    |      |

Date: 3/9/24

Shift: N

Name: \_\_\_\_\_

Unit 2

|  |                        |         |
|--|------------------------|---------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 55                     | 12B     |
| Heat Exchanger Parallel Operation  | <u>North and South</u> |         |
| Cooling Water Heat Exchanger Inlet Temperature   | 56                     | 160     |
| Cooling Water Heat Exchanger Outlet Temperature  | 60                     | 155     |
| Cooling Water Heat Exchanger Discharge Pressure  | 55                     | 156     |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 0                      | 10      |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 40                     | 140     |
| 2B DA Pump Discharge Pressure  | 0                      |         |
| 2B DA Pump Bearing Lube Oil Pressure   | 3                      |         |
| 2A DA Pump Discharge Pressure  | 0                      |         |
| 2A DA Pump Bearing Lube Oil Pressure   | 3                      |         |
| MBFP/SUBFP Gland Water Pressure  | 0                      |         |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10                     | (AC)149 |
| Coupling Oil Temperature   | 73                     |         |
| Turbine Oil Temperature  | 70                     |         |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 0                      |         |
| Condenser Inlet Temperature  | 43                     |         |
| Condenser Outlet Temperature East / West   | 49                     | 149     |
| Condenser Inlet Pressure East / West   | 0 10                   |         |
| Air Side/Gas Side Seal Oil Temperature   | 75                     | 175     |
| Hydrogen Dew Point / Hydrogen Purity   | -135.2 / 100.1         |         |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 39.6                   | 1.4     |
| Flyash Blower Pressure North/South   | 0 10                   |         |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | ACL                    |         |
| Supplemental Precip Flyash Blower Discharge Pressure   | 0                      |         |
| Supplemental Precip Flyash Hoppers in Bypass   | ACL                    |         |
| Kaydon System Pressure / Water Meter Reading   | 5                      | 14170   |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓                      |         |
| TA-6040 Discharge pressure/Oil temperature   | 1.4                    | 191     |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 45       |          |           |          |          |        |
| T24 | 59       |          |           |          |          |        |
| ST2 | 35       | 35       | —         | .5       |          |        |
| RT2 | X1- 10   | 10       | —         | .5       | 1800     |        |
|     | X2- 10   |          |           |          |          |        |
| MT2 | 15       | 10       | —         | 1        | 1750     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |      |
|---|---|----|------|
| Circulators in operation  | 2A  | 2B | Both |
| Screen house Recirc valve position  |   | 25 | %    |
| Forebay Frozen?   | YES   | NO |      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |    |      |



Date: 3/10/24

Shift: D

Name: \_\_\_\_\_

Unit 2

|  |            |
|--|------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 57 1 28    |
| Heat Exchanger Parallel Operation North and South  |            |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 45 1 45    |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 43 1 43    |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55 1 57    |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 0 1 0      |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 44 1 40    |
| 2B DA Pump Discharge Pressure  | 0          |
| 2B DA Pump Bearing Lube Oil Pressure   | 4          |
| 2A DA Pump Discharge Pressure  | 0          |
| 2A DA Pump Bearing Lube Oil Pressure   | 3          |
| MBFP/SUBFP Gland Water Pressure  | 0          |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 1 132   |
| Coupling Oil Temperature   | 75         |
| Turbine Oil Temperature  | 73         |
| Turbine Oil Vapor Extractor Vacuum "H20  | 4          |
| Condenser Inlet Temperature  | 39         |
| Condenser Outlet Temperature East / West   | 37 1 39    |
| Condenser Inlet Pressure East / West   | 3 1 3.5    |
| Air Side/Gas Side Seal Oil Temperature   | 75 1 76    |
| Hydrogen Dew Point / Hydrogen Purity   | -84.31 100 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 39 1 1.3   |
| Flyash Blower Pressure North/South   | 0 1 0      |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | ALL        |
| Supplemental Precip Flyash Blower Discharge Pressure   | 0          |
| Supplemental Precip Flyash Hoppers in Bypass   | ALL        |
| Kaydon System Pressure / Water Meter Reading   | 5 1 41755  |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | OK         |
| TA-6040 Discharge pressure/Oil temperature   | 1.4 1 93   |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 50       |          |           |          |          |        |
| T24 | 71       |          |           |          |          |        |
| ST2 | 35       | 35       | -         | 1        |          |        |
| RT2 | X1- 8    | 5        | -         | 1        | 1750     |        |
|     | X2- 8    |          |           |          |          |        |
| MT2 | 10       | 10       | -         | 1.5      | 1700     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |   |         |
|---|---|---------|
| Circulators in operation  | 2A  | 2B Both |
| Screen house Recirc valve position  |   | 0 %     |
| Forebay Frozen?   | YES   | NO      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |         |
|   | NO  |         |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |         |

Date: 3/11/24

Shift: N

Name: LOWELL

Unit 2

|  |        |          |
|--|--------|----------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 50     | 12A      |
| Heat Exchanger Parallel Operation North and South  |        |          |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 49     | 149      |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 43     | 142      |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55     | 150      |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 0      | 10       |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 50     | 143      |
| 2B DA Pump Discharge Pressure  | 150    |          |
| 2B DA Pump Bearing Lube Oil Pressure   | 3      |          |
| 2A DA Pump Discharge Pressure  | 160    |          |
| 2A DA Pump Bearing Lube Oil Pressure   | 3      |          |
| MBFP/SUBFP Gland Water Pressure  | 100    |          |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10     | (2A) 160 |
| Coupling Oil Temperature   | 65     |          |
| Turbine Oil Temperature  | 75     |          |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2.75   |          |
| Condenser Inlet Temperature  | 40     |          |
| Condenser Outlet Temperature East / West   | 40     | 140      |
| Condenser Inlet Pressure East / West   |        | 3LB 3LB  |
| Air Side/Gas Side Seal Oil Temperature   | 40     | 170      |
| Hydrogen Dew Point / Hydrogen Purity   | -131.6 | 100      |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 41.8   | 1.3      |
| Flyash Blower Pressure North/South   | 5      | 15       |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | NONE   |          |
| Supplemental Precip Flyash Blower Discharge Pressure   | 2.4    |          |
| Supplemental Precip Flyash Hoppers in Bypass   | 2      |          |
| Kaydon System Pressure / Water Meter Reading   | 5      | 14170    |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓      |          |
| TA-6040 Discharge pressure/Oil temperature   | 1.4    | 193      |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 46       |          |           |          |          |        |
| T24 | 59       |          |           |          |          |        |
| ST2 | 40       | 35       | —         | .5       |          |        |
| RT2 | X1- 20   | 20       | —         | .5       | 1750     |        |
|     | X2- 20   |          |           |          |          |        |
| MT2 | 44       | 44       | —         | 3        | 1700     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |   |         |
|---|---|---------|
| Circulators in operation                                    | (2A)  | 2B Both |
| Screen house Recirc valve position                          |   | 0 %     |
| Forebay Frozen?   | YES   | (NO)    |
| Is there evidence of Deicing water being released to river? | If YES close off on the Screen house Recirc valve until there is no flow. |         |
|   | (NO)  |         |

NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service.

2103  
6354  
80762

EOD - EA

Date: 3-12-24

Shift: D

Name: AP

Unit 2

|  |             |
|--|-------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 213 1 55    |
| Heat Exchanger Parallel Operation North and South  |             |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 44 1 46     |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 44 1 44     |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55 1 55     |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 0 1 0       |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 50 1        |
| 2B DA Pump Discharge Pressure  | 0           |
| 2B DA Pump Bearing Lube Oil Pressure   | 4           |
| 2A DA Pump Discharge Pressure  | 0           |
| 2A DA Pump Bearing Lube Oil Pressure   | 3           |
| MBFP/SUBFP Gland Water Pressure  | 0           |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 1 138    |
| Coupling Oil Temperature   | 60          |
| Turbine Oil Temperature  | 87          |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2.6         |
| Condenser Inlet Temperature  | 40          |
| Condenser Outlet Temperature East / West   | 37 1 40     |
| Condenser Inlet Pressure East / West   | 3 1 4       |
| Air Side/Gas Side Seal Oil Temperature   | 75 1 68     |
| Hydrogen Dew Point / Hydrogen Purity   | -415 1 100  |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 44.81 .3    |
| Flyash Blower Pressure North/South   | 3.8 13.9    |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 10, 7, 4, 3 |
| Supplemental Precip Flyash Blower Discharge Pressure   | 2.4         |
| Supplemental Precip Flyash Hoppers in Bypass   | 1/0/0/2     |
| Kaydon System Pressure / Water Meter Reading   | 5 14 176    |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | OK          |
| TA-6040 Discharge pressure/Oil temperature   | 1.4 192     |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 49       |          |           |          |          |        |
| T24 | 68       |          |           |          |          |        |
| ST2 | 40       | 35       | -         | 1        |          |        |
| RT2 | X1- 20   | 18       | -         | 1.5      | 1750     |        |
|     | X2- 20   |          |           |          |          |        |
| MT2 | 30       | 35       | +         | 2.5      | 1750     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |   |         |
|---|---|---------|
| Circulators in operation                                    | 2A  | 2B Both |
| Screen house Recirc valve position                          |   | %       |
| Forebay Frozen?   | YES   | NO      |
| Is there evidence of Deicing water being released to river? | If YES close off on the Screen house Recirc valve until there is no flow. |         |
|   | NO  |         |

NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service.

80762  
2104  
6355

Date: 13 MAR 24

Shift: N

Name: ERIK R

Unit 2

|  |             |
|--|-------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 60 12B      |
| Heat Exchanger Parallel Operation North and South  |             |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 44 144      |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 46 143      |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55 150      |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 0 1 0       |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 0 1 0       |
| 2B DA Pump Discharge Pressure  | 0           |
| 2B DA Pump Bearing Lube Oil Pressure   | 3           |
| 2A DA Pump Discharge Pressure  | 0           |
| 2A DA Pump Bearing Lube Oil Pressure   | 3           |
| MBFP/SUBFP Gland Water Pressure  | 0           |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 (AC) 135 |
| Coupling Oil Temperature   | 65          |
| Turbine Oil Temperature  | 75          |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2.75        |
| Condenser Inlet Temperature  | 55          |
| Condenser Outlet Temperature East / West   | 50 151      |
| Condenser Inlet Pressure East / West   | 0 1 0       |
| Air Side/Gas Side Seal Oil Temperature   | 42 169      |
| Hydrogen Dew Point / Hydrogen Purity   | -87.7 100   |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 41 1.3      |
| Flyash Blower Pressure North/South   | 0 1 0       |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 3, 4, 7, 10 |
| Supplemental Precip Flyash Blower Discharge Pressure   | 0           |
| Supplemental Precip Flyash Hoppers in Bypass   | 0           |
| Kaydon System Pressure / Water Meter Reading   | 5 14170     |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓           |
| TA-6040 Discharge pressure/Oil temperature   | 1.4 196     |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 54       |          |           |          |          |        |
| T24 | 57       |          |           |          |          |        |
| ST2 | 40       | 40       | -         | 1        |          |        |
| RT2 | X1- 20   | 20       | -         | 1        | 1700     |        |
|     | X2- 20   |          |           |          |          |        |
| MT2 | 30       | 30       | -         | 1.5      | 1700     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |      |
|---|---|----|------|
|   | 2A  | 2B | Both |
| Circulators in operation  |   |    |      |
| Screen house Recirc valve position  |   | 25 | %    |
| Forebay Frozen?   | YES   | NO |      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |    |      |



Date: 3-25

Shift: Day

Name: Shain

Unit 2

|  |               |        |
|--|---------------|--------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 60            | 12B    |
| Heat Exchanger Parallel Operation North and South  |               |        |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 80            | 180    |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 820           | 160    |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55            | 157    |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | <del>62</del> | 1      |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 62            | 150    |
| 2B DA Pump Discharge Pressure  | 375           |        |
| 2B DA Pump Bearing Lube Oil Pressure   | 3             |        |
| 2A DA Pump Discharge Pressure  | 425           |        |
| 2A DA Pump Bearing Lube Oil Pressure   | 3             |        |
| MBFP/SUBFP Gland Water Pressure  | 250           |        |
| Coupling Oil Pump Discharge Pressure   | 169           |        |
| Coupling Oil Pump Suction Pressure   | 11            |        |
| Coupling Oil Temperature   | 110° F        |        |
| Turbine Oil Temperature  | 110° F        |        |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 1 3/4         |        |
| Condenser Inlet Temperature  | 40°           |        |
| Condenser Outlet Temperature East / West   | 80°           | 178°   |
| Condenser Inlet Pressure East / West   | 4             | 14     |
| Air Side/Gas Side Seal Oil Temperature   | 110°          | 110°   |
| Hydrogen Dew Point / Hydrogen Purity   | 160.8°F       | 100.0  |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 50.4          | 164.9  |
| SBAC Cooling Water Supply Pressure   | 1.4           |        |
| SBAC Discharge Air Pressure  | 1.4           |        |
| SBAC Fourth Stage Inlet Temperature  | 58            |        |
| SBAC Evacuator Vacuum "H2O   | 47.50         |        |
| SBAC Oil Temperature   | 87            |        |
| SBAC Lube Oil Pressure   | 132.0         |        |
| Flyash Blower Pressure North/South   | 44            | 14.9   |
| Precipitator Flyash hopper(s) alarms in By-pass  | 0             |        |
| Precipitator Flyash hopper(s) in By-pass   | 0             |        |
| Supplemental Precip Flyash Blower Discharge Pressure   | 3             |        |
| Supplemental Precip Flyash Hopper(s) in By-pass  | 0             |        |
| Scr/Eco Flyash Blower Pressure   | 0             |        |
| Scr or Eco Flyash system in Bypass   |               |        |
| Hypo Tank Level  |               |        |
| Kaydon System Pressure / Water Meter Reading   | 0             | 141707 |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | Good          |        |
| Comments:  |               |        |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 48       |          |           |          |          |        |
| T24 | 70       |          |           |          |          |        |
| ST2 | 40       | 40       | -         | 0        |          |        |
| RT2 | X1- 30   | 25       | -         | 3        | 1200     |        |
|     | X2- 30   |          |           |          |          |        |
| MT2 | 45       | 45       | 25°       | 3.5      | 1500     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

Date: 03/25/24

Shift: night

Name: Jade

Unit 2

|  |   |
|--|---|
| Cooling Water Pump Discharge Pressure / Pumps in service   | <del>155</del> / 26                     |
| Heat Exchanger Parallel Operation North and South  |   |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 86 / 87                                 |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 75 / 68                                 |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 0 / -2                                  |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 10 / 8                                  |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 60 / 54                                 |
| 2B DA Pump Discharge Pressure  | 3                                       |
| 2B DA Pump Bearing Lube Oil Pressure   | 400                                     |
| 2A DA Pump Discharge Pressure  | 440                                     |
| 2A DA Pump Bearing Lube Oil Pressure   | 2.5                                     |
| MBFP/SUBFP Gland Water Pressure  | 280                                     |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 / 155                                |
| Coupling Oil Temperature   | 120                                     |
| Turbine Oil Temperature  | 105                                     |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2.4                                     |
| Condenser Inlet Temperature  | 40                                      |
| Condenser Outlet Temperature East / West   | 70 / 70                                 |
| Condenser Inlet Pressure East / West   | 104 / 104                               |
| Air Side/Gas Side Seal Oil Temperature   | 110 / 105                               |
| Hydrogen Dew Point / Hydrogen Purity   | -107 / 100                              |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 58.1 / 13.5                             |
| Flyash Blower Pressure North/South   | 4.6 / 3.9                               |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | #2/#3/#4/#7/#10                         |
| Supplemental Precip Flyash Blower Discharge Pressure   | 2.7                                     |
| Supplemental Precip Flyash Hoppers in Bypass   |   |
| Kaydon System Pressure / Water Meter Reading   | 5 / 4178                                |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | fire main throttled for aiding slugging |
| TA-6040 Discharge pressure/Oil temperature   | 1                                       |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 53       |          |           |          |          |        |
| T24 | 76       |          |           |          |          |        |
| ST2 | 35       | 35       | -         | 0        |          |        |
| RT2 | X1- 46   | 36       | -         | 3        | 1300     |        |
|     | X2- 44   |          |           |          |          |        |
| MT2 | 65       | 65       | +         | 3.5      | 1600     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |          |
|---|---|----|----------|
|   | 2A  | 2B |          |
| Circulators in operation  |   |    | Both     |
| Screen house Recirc valve position  |   |    | % Closed |
| Forebay Frozen?   | YES   | NO |          |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO       |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |    |          |

Date: 7/9/24

Shift: \_\_\_\_\_

Name: \_\_\_\_\_

Unit 2

|  |              |
|--|--------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   |              |
| Heat Exchanger Parallel Operation North and South  |              |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 1 80         |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 1 74         |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 1 0          |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 1            |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 1            |
| 2B DA Pump Discharge Pressure  | 3            |
| 2B DA Pump Bearing Lube Oil Pressure   |              |
| 2A DA Pump Discharge Pressure  | 3            |
| 2A DA Pump Bearing Lube Oil Pressure   |              |
| MBFP/SUBFP Gland Water Pressure  |              |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 1            |
| Coupling Oil Temperature   |              |
| Turbine Oil Temperature  |              |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 5            |
| Condenser Inlet Temperature  |              |
| Condenser Outlet Temperature East / West   | 1            |
| Condenser Inlet Pressure East / West   | 1            |
| Air Side/Gas Side Seal Oil Temperature   | 1            |
| Hydrogen Dew Point / Hydrogen Purity   | -78.7 / 99.1 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 40.8 / 1     |
| Flyash Blower Pressure North/South   | 1            |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   |              |
| Supplemental Precip Flyash Blower Discharge Pressure   |              |
| Supplemental Precip Flyash Hoppers in Bypass   |              |
| Kaydon System Pressure / Water Meter Reading   | 1            |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. |              |
| TA-6040 Discharge pressure/Oil temperature   | 1            |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 68       |          |           |          |          |        |
| T24 | 75       |          |           |          |          |        |
| ST2 | 45       | 45       | +         | 2        |          |        |
| RT2 | X1- 25   | 25       | +         | 1.5      | 700      |        |
|     | X2- 25   |          |           |          |          |        |
| MT2 | 20       | 35       | +         | 1        | 1300     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |         |      |
|---|---|---------|------|
|   | 2A  | 2B      | Both |
| Circulators in operation                                    |   |         |      |
| Screen house Recirc valve position                          |   | checked | %    |
| Forebay Frozen?   | YES   | NO      |      |
| Is there evidence of Deicing water being released to river? | If YES close off on the Screen house Recirc valve until there is no flow. |         | NO   |

NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service.

power-6906  
SUR-2205  
SBAC-85085



Date: 7/10/24

Shift: D

Name: AD

Unit 2

|  |             |
|--|-------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65 1A+B     |
| Heat Exchanger Parallel Operation North and South  |             |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 108 1109    |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 96 198      |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 63 158      |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 13 1 20     |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 44 189      |
| 2B DA Pump Discharge Pressure  | 390         |
| 2B DA Pump Bearing Lube Oil Pressure   | 35          |
| 2A DA Pump Discharge Pressure  | 425         |
| 2A DA Pump Bearing Lube Oil Pressure   | 25          |
| MBFP/SUBFP Gland Water Pressure  | 275         |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 1152     |
| Coupling Oil Temperature   | 128         |
| Turbine Oil Temperature  | 125         |
| Turbine Oil Vapor Extractor Vacuum "H20  | 4.0         |
| Condenser Inlet Temperature  | 78          |
| Condenser Outlet Temperature East / West   | 98 198      |
| Condenser Inlet Pressure East / West   | 3 13.1      |
| Air Side/Gas Side Seal Oil Temperature   | 125 1120    |
| Hydrogen Dew Point / Hydrogen Purity   | -48.5 199.4 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.8 173.9  |
| Flyash Blower Pressure North/South   | 4.3 14.7    |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 5, 7, 8     |
| Supplemental Precip Flyash Blower Discharge Pressure   | 3.2         |
| Supplemental Precip Flyash Hoppers in Bypass   | 1/01/E      |
| Kaydon System Pressure / Water Meter Reading   | 0 14182     |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | OK          |
| TA-6040 Discharge pressure/Oil temperature   | 251 1129    |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 81       |          |           |          |          |        |
| T24 | 106      |          |           |          |          |        |
| ST2 | 50       | 50       | +         | 2        |          |        |
| RT2 | X1- 70   | 62       | +         | 25       | 450      |        |
|     | X2- 70   |          |           |          |          |        |
| MT2 | 65       | 65       | +         | 3.2      | 1650     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |      |
|---|---|----|------|
| Circulators in operation  | 2A  | 2B | Both |
| Screen house Recirc valve position  |   | 0  | %    |
| Forebay Frozen?   | YES   | NO |      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |    |      |



Date: 7/11/24

Shift: D

Name: A

Unit 2

|  |                    |
|--|--------------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65 1A+B            |
| Heat Exchanger Parallel Operation North and South  |                    |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 110 198            |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | <del>110</del> 202 |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 62 158             |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 10 187             |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | <del>88</del> 175  |
| 2B DA Pump Discharge Pressure  | 350                |
| 2B DA Pump Bearing Lube Oil Pressure   | 35                 |
| 2A DA Pump Discharge Pressure  | 375                |
| 2A DA Pump Bearing Lube Oil Pressure   | 25                 |
| MBFP/SUBFP Gland Water Pressure  | 250                |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 1165            |
| Coupling Oil Temperature   | 125                |
| Turbine Oil Temperature  | 125                |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2.8                |
| Condenser Inlet Temperature  | 80                 |
| Condenser Outlet Temperature East / West   | 108 164            |
| Condenser Inlet Pressure East / West   | 3.1 3.1            |
| Air Side/Gas Side Seal Oil Temperature   | 130 125            |
| Hydrogen Dew Point / Hydrogen Purity   | -34.41 99          |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 60 173.8           |
| Flyash Blower Pressure North/South   | 4.2 4.1            |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 0                  |
| Supplemental Precip Flyash Blower Discharge Pressure   | 4.1                |
| Supplemental Precip Flyash Hoppers in Bypass   | 0                  |
| Kaydon System Pressure / Water Meter Reading   | 0 14182            |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ok                 |
| TA-6040 Discharge pressure/Oil temperature   | 253 132            |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 99       |          |           |          |          |        |
| T24 | 111      |          |           |          |          |        |
| ST2 | 55       | 55       | +         | 3        |          |        |
| RT2 | X1- 75   | 80       | +         | 2.5      | 350      |        |
|     | X2- 75   |          |           |          |          |        |
| MT2 | 75       | 90       | +         | 1600     | 4.5      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |      |
|---|---|----|------|
|   | 2A  | 2B |      |
| Circulators in operation  |   |    | Both |
| Screen house Recirc valve position  |   |    | %    |
| Forebay Frozen?   | YES   | NO |      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |    |      |

Date: 7-11-24

Shift: N

Name: Bungat

Unit 2

|  |               |
|--|---------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65-60 / A + B |
| Heat Exchanger Parallel Operation North and South  |               |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 112 / 112     |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 100 / 100     |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 56 / 58       |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 8 / 8         |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 74 / 82       |
| 2B DA Pump Discharge Pressure  | 340           |
| 2B DA Pump Bearing Lube Oil Pressure   | 3             |
| 2A DA Pump Discharge Pressure  | 375           |
| 2A DA Pump Bearing Lube Oil Pressure   | 2.5           |
| MBFP/SUBFP Gland Water Pressure  | 260           |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 / 165      |
| Coupling Oil Temperature   | 125           |
| Turbine Oil Temperature  | 125           |
| Turbine Oil Vapor Extractor Vacuum "H20  | 2.8           |
| Condenser Inlet Temperature  | 80            |
| Condenser Outlet Temperature East / West   | 108 / 105     |
| Condenser Inlet Pressure East / West   | 3 / 3         |
| Air Side/Gas Side Seal Oil Temperature   | 80 / 78       |
| Hydrogen Dew Point / Hydrogen Purity   | -8.8 / 98.8   |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.6 / 73.8   |
| Flyash Blower Pressure North/South   | 5 / 5         |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 1, 3, 7, 10   |
| Supplemental Precip Flyash Blower Discharge Pressure   | 11            |
| Supplemental Precip Flyash Hoppers in Bypass   |               |
| Kaydon System Pressure / Water Meter Reading   | 5 / 418       |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓             |
| TA-6040 Discharge pressure/Oil temperature   | 1             |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 90       |          |           |          |          |        |
| T24 | 93       |          |           |          |          |        |
| ST2 | 55       | 55       | +         | 2        |          |        |
| RT2 | X1- 86   | 70       | +         | 1.5      | 450      | —      |
|     | X2- 80   |          |           |          |          |        |
| MT2 | 85       | 85       | +         | 3        | 1700     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |   |
|---|---|
| Circulators in operation  | 2A                      2B                      Both  |
| Screen house Recirc valve position  | 0 %   |
| Forebay Frozen?   | YES                      NO   |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow.                      NO |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |

SBAL 81992  
 SLR 2161  
 ASMTA 6537.664



Date: 7/12/24

Shift: day

Name: Jackie

Unit 2

|  |                    |
|--|--------------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65.60/both         |
| Heat Exchanger Parallel Operation North and South  |                    |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 108 / 110          |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 98 / 100           |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | -3 / -8            |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 5 / 5              |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 20 / 21            |
| 2B DA Pump Discharge Pressure  | 3.5                |
| 2B DA Pump Bearing Lube Oil Pressure   | 3.0                |
| 2A DA Pump Discharge Pressure  | 2.5                |
| 2A DA Pump Bearing Lube Oil Pressure   | <del>2.0</del> 2   |
| MBFP/SUBFP Gland Water Pressure  | 2.90               |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10.810/160         |
| Coupling Oil Temperature   | 127                |
| Turbine Oil Temperature  | 127                |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 5                  |
| Condenser Inlet Temperature  | 80                 |
| Condenser Outlet Temperature East / West   | 100 / 100          |
| Condenser Inlet Pressure East / West   | <del>103</del> 3   |
| Air Side/Gas Side Seal Oil Temperature   | 125 / 120          |
| Hydrogen Dew Point / Hydrogen Purity   | -50 / 93.9         |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.6 / 177.3       |
| Flyash Blower Pressure North/South   | 4 / 15             |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 0 / 13.79          |
| Supplemental Precip Flyash Blower Discharge Pressure   | <del>100</del> 110 |
| Supplemental Precip Flyash Hoppers in Bypass   | 0                  |
| Kaydon System Pressure / Water Meter Reading   | 0 / 14182          |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓                  |
| TA-6040 Discharge pressure/Oil temperature   | 250 / 130          |

TRANSFORMERS

|     | WDG TEMP         | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|------------------|----------|-----------|----------|----------|--------|
| 2TX | 87               |          |           |          |          |        |
| T24 | 105              |          |           |          |          |        |
| ST2 | 55               | 50       | +         | 2        |          |        |
| RT2 | X1- 75<br>X2- 75 | 65       | +         | 1        | 400      |        |
| MT2 | 70               | 60       | +         | 2.5      | 1650     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| Circulators in operation  | River Info  |           |                 |
|---|---|-----------|-----------------|
|   | 2A  | 2B        | Both            |
| Screen house Recirc valve position  |   |           | % <u>closed</u> |
| Forebay Frozen?   | YES   | <u>NO</u> |                 |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |           | <u>NO</u>       |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |           |                 |



Date: 7/13/21

Shift: day

Name: Jade

Unit 2

|  |              |
|--|--------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65.60 / A+B  |
| Heat Exchanger Parallel Operation North and South  |              |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 110 / 110    |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 99 / 102     |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | -3 / -8      |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 7 / 6        |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 80 / 70      |
| 2B DA Pump Discharge Pressure  | 3.5          |
| 2B DA Pump Bearing Lube Oil Pressure   | 4            |
| 2A DA Pump Discharge Pressure  | 2.5          |
| 2A DA Pump Bearing Lube Oil Pressure   | 1.5          |
| MBFP/SUBFP Gland Water Pressure  | 280          |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 / 1160    |
| Coupling Oil Temperature   | 130          |
| Turbine Oil Temperature  | 130          |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 3            |
| Condenser Inlet Temperature  | 80           |
| Condenser Outlet Temperature East / West   | 100 / 100    |
| Condenser Inlet Pressure East / West   | 11 / 11      |
| Air Side/Gas Side Seal Oil Temperature   | 125 / 120    |
| Hydrogen Dew Point / Hydrogen Purity   | -41.5 / 98.7 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 60.4 / 79.4  |
| Flyash Blower Pressure North/South   | 4.4 / 5.4    |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 1,379,10     |
| Supplemental Precip Flyash Blower Discharge Pressure   | 11           |
| Supplemental Precip Flyash Hoppers in Bypass   | 0            |
| Kaydon System Pressure / Water Meter Reading   | 0 / 14182    |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓            |
| TA-6040 Discharge pressure/Oil temperature   | 250 / 187    |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 32       |          |           |          |          |        |
| T24 | 105      |          |           |          |          |        |
| ST2 | 55       | 50       | +         | 1.5      |          |        |
| RT2 | X1- 10   | 62       | +         | .5       | 400      |        |
|     | X2- 70   |          |           |          |          |        |
| MT2 | 70       | 75       | +         | 2.5      | 1600     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |          |
|---|---|----|----------|
|   | 2A  | 2B | Both     |
| Circulators in operation                                    |   |    | Both     |
| Screen house Recirc valve position                          |   |    | % closed |
| Forebay Frozen?   | YES   | NO |          |
| Is there evidence of Deicing water being released to river? | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO       |

NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service.



Date: 7/14/24

Shift: DAY

Name: \_\_\_\_\_

Unit 2

|  |                  |
|--|------------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65+60/A+B        |
| Heat Exchanger Parallel Operation North and South  |                  |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 110 / 110        |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 100 / 100        |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | -3 / -3          |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 6 / 7            |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 80 / 70          |
| 2B DA Pump Discharge Pressure  | 3.5              |
| 2B DA Pump Bearing Lube Oil Pressure   | 3.5              |
| 2A DA Pump Discharge Pressure  | 2.5              |
| 2A DA Pump Bearing Lube Oil Pressure   | 3                |
| MBFP/SUBFP Gland Water Pressure  | 280              |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 11 / 155         |
| Coupling Oil Temperature   | 130              |
| Turbine Oil Temperature  | 130              |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 3                |
| Condenser Inlet Temperature  | 86 / 80          |
| Condenser Outlet Temperature East / West   | 100 / 100        |
| Condenser Inlet Pressure East / West   | 4 / 4            |
| Air Side/Gas Side Seal Oil Temperature   | 125 / 125        |
| Hydrogen Dew Point / Hydrogen Purity   | -46.1 / 98.5     |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 60.4 / 81.1      |
| Flyash Blower Pressure North/South   | 9.4 / 5          |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 0 / 1,3,6,7,9,10 |
| Supplemental Precip Flyash Blower Discharge Pressure   | 11               |
| Supplemental Precip Flyash Hoppers in Bypass   | 0                |
| Kaydon System Pressure / Water Meter Reading   | 0 / 14178        |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓                |
| TA-6040 Discharge pressure/Oil temperature   | 255 / 130        |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 78       |          |           |          |          |        |
| T24 | 104      |          |           |          |          |        |
| ST2 | 55       | 50       | t         | ?        |          |        |
| RT2 | X1- 75   | 65       | t         | 1        | 4100     | 440    |
|     | X2- 75   |          |           |          |          |        |
| MT2 | 70       | 60       | t         | 2.5      | 1600     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |          |
|---|---|----|----------|
| Circulators in operation  | 2A  | 2B | Both     |
| Screen house Recirc valve position  |   |    | % closed |
| Forebay Frozen?   | YES   | NO |          |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO       |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |    |          |

Date: 7-14-24

Shift: N

Name: ERIK

Unit 2

|  |              |
|--|--------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65/60 12A/2B |
| Heat Exchanger Parallel Operation North and South  |              |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 110 110      |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 100 110      |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55 1         |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 809 17012    |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 80 170       |
| 2B DA Pump Discharge Pressure  | 2.5 35       |
| 2B DA Pump Bearing Lube Oil Pressure   | 2.5          |
| 2A DA Pump Discharge Pressure  | 2.5          |
| 2A DA Pump Bearing Lube Oil Pressure   | 2            |
| MBFP/SUBFP Gland Water Pressure  | 255          |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 1155      |
| Coupling Oil Temperature   | 125          |
| Turbine Oil Temperature  | 125          |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 3.2          |
| Condenser Inlet Temperature  | 80           |
| Condenser Outlet Temperature East / West   | 100 100      |
| Condenser Inlet Pressure East / West   | -3 1+3       |
| Air Side/Gas Side Seal Oil Temperature   | 125 125      |
| Hydrogen Dew Point / Hydrogen Purity   | -41.6 98.4   |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.6 179.5   |
| Flyash Blower Pressure North/South   | 3.8 14.0     |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 1,3,6,7,9,10 |
| Supplemental Precip Flyash Blower Discharge Pressure   | 3.2          |
| Supplemental Precip Flyash Hoppers in Bypass   | NONE         |
| Kaydon System Pressure / Water Meter Reading   | 5 14180      |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓            |
| TA-6040 Discharge pressure/Oil temperature   | 1            |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 110 83   |          |           |          |          |        |
| T24 | 110      |          |           |          |          |        |
| ST2 | 50       | 50       | +         | 2        |          |        |
| RT2 | X1- 72   | 70       | +         | 1        | 400      |        |
|     | X2- 72   |          |           |          |          |        |
| MT2 | 60       | 60       | +         | 2.5      | 1600     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |      |
|---|---|----|------|
|   | 2A  | 2B |      |
| Circulators in operation  |   |    | Both |
| Screen house Recirc valve position  |   |    | %    |
| Forebay Frozen?   | YES   | NO |      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |    |      |

2177  
6005  
2697



Date: 7-14-24

Shift: N

Name: ROBERT L

Unit 2

|  |                          |                                     |
|--|--------------------------|-------------------------------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | <del>60/60</del> / 2A+2B |                                     |
| Heat Exchanger Parallel Operation  | North and South          |                                     |
| Cooling Water Heat Exchanger Inlet Temperature   | North / South            | 110 1110                            |
| Cooling Water Heat Exchanger Outlet Temperature  | North / South            | 100 1100                            |
| Cooling Water Heat Exchanger Discharge Pressure  | North / South            | 55 156                              |
| Air In-leakage @ 2A / 2B Vacuum Pumps  |                          | 19 120                              |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   |                          | 80 165                              |
| 2B DA Pump Discharge Pressure  |                          | 35                                  |
| 2B DA Pump Bearing Lube Oil Pressure   |                          | 3.5                                 |
| 2A DA Pump Discharge Pressure  |                          | 2                                   |
| 2A DA Pump Bearing Lube Oil Pressure   |                          | 2.5                                 |
| MBFP/SUBFP Gland Water Pressure  |                          | 265                                 |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  |                          | 10 1160                             |
| Coupling Oil Temperature   |                          | 130                                 |
| Turbine Oil Temperature  |                          | 120                                 |
| Turbine Oil Vapor Extractor Vacuum "H2O  |                          | 3                                   |
| Condenser Inlet Temperature  |                          | <del>10</del> 80                    |
| Condenser Outlet Temperature East / West   |                          | 100 1100                            |
| Condenser Inlet Pressure East / West   |                          | 3 1.3                               |
| Air Side/Gas Side Seal Oil Temperature   |                          | 127 1125                            |
| Hydrogen Dew Point / Hydrogen Purity   |                          | -32.1 198.1                         |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  |                          | 60 181.3                            |
| Flyash Blower Pressure North/South   |                          | 4.7 15.6                            |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   |                          | 13 7 10                             |
| Supplemental Precip Flyash Blower Discharge Pressure   |                          | 3                                   |
| Supplemental Precip Flyash Hoppers in Bypass   |                          | NONE                                |
| Kaydon System Pressure / Water Meter Reading   |                          | 5 14180                             |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. |                          | <input checked="" type="checkbox"/> |
| TA-6040 Discharge pressure/Oil temperature   |                          | 244 1131                            |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 84       |          |           |          |          |        |
| T24 | 113      |          |           |          |          |        |
| ST2 | 53       | 50       | +         | 2        |          |        |
| RT2 | X1- 66   | 63       | +         | 1        | 400      |        |
|     | X2- 66   |          |           |          |          |        |
| MT2 | 62       | 62       | +         | 2.5      | 1600     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |      |      |
|---|---|------|------|
|   | 2A  | 2B   |      |
| Circulators in operation  |   |      | Both |
| Screen house Recirc valve position  |   | 100% |      |
| Forebay Frozen?   | YES   | NO   |      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |      | NO   |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |      |      |

Date: 7/15/24

Shift: night

Name: Croissant

Unit 2

|  |              |
|--|--------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65/60/both   |
| Heat Exchanger Parallel Operation North and South  |              |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 110 / 113    |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 101 / 102    |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | -3 / -11     |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 5 / 6        |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 82 / 72      |
| 2B DA Pump Discharge Pressure  | 3.5          |
| 2B DA Pump Bearing Lube Oil Pressure   | 4            |
| 2A DA Pump Discharge Pressure  | 2.5          |
| 2A DA Pump Bearing Lube Oil Pressure   | 4            |
| MBFP/SUBFP Gland Water Pressure  | 290          |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 11 / 162     |
| Coupling Oil Temperature   | 130          |
| Turbine Oil Temperature  | 130          |
| Turbine Oil Vapor Extractor Vacuum "H2O"   | 3            |
| Condenser Inlet Temperature  | 80           |
| Condenser Outlet Temperature East / West   | 100 / 100    |
| Condenser Inlet Pressure East / West   | 4 / 4        |
| Air Side/Gas Side Seal Oil Temperature   | 132 / 125    |
| Hydrogen Dew Point / Hydrogen Purity   | -11.1 / 97.8 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.7 / 83.7  |
| Flyash Blower Pressure North/South   | 4.5 / 3.9    |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 1,3,5,7,9,10 |
| Supplemental Precip Flyash Blower Discharge Pressure   | 13           |
| Supplemental Precip Flyash Hoppers in Bypass   | 0            |
| Kaydon System Pressure / Water Meter Reading   | 0 / 14182    |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓            |
| TA-6040 Discharge pressure/Oil temperature   | 248 / 133    |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 86       |          |           |          |          |        |
| T24 | 116      |          |           |          |          |        |
| ST2 | 50       | 60       | +         | 3        |          |        |
| RT2 | X1- 70   | 70       | +         | 2.5      | 400      |        |
|     | X2- 70   |          |           |          |          |        |
| MT2 | 70       | 70       | +         | 3.5      | 1606     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |          |
|---|---|----|----------|
| Circulators in operation  | 2A  | 2B | Both     |
| Screen house Recirc valve position  |   |    | % closed |
| Forebay Frozen?   | YES   | NO |          |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO       |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |    |          |

power spray-k 5  
SCR-2174  
SBAC-83311



Date: 7/16/24

Shift: night

Name: Jade Croissant

Unit 2

|  |                                   |
|--|-----------------------------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65/60 / A+B                       |
| Heat Exchanger Parallel Operation North and South  |                                   |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 110 / 110                         |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 98 / 100                          |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | -2 / -10                          |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 8 / 17                            |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 80 / 70                           |
| 2B DA Pump Discharge Pressure  | 3.5                               |
| 2B DA Pump Bearing Lube Oil Pressure   | 4                                 |
| 2A DA Pump Discharge Pressure  | 2.5                               |
| 2A DA Pump Bearing Lube Oil Pressure   | 1                                 |
| MBFP/SUBFP Gland Water Pressure  | 290                               |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 / 15.5                         |
| Coupling Oil Temperature   | 130                               |
| Turbine Oil Temperature  | 130                               |
| Turbine Oil Vapor Extractor Vacuum "H2O"   | 2                                 |
| Condenser Inlet Temperature  | 80                                |
| Condenser Outlet Temperature East / West   | 100 / 100                         |
| Condenser Inlet Pressure East / West   | 4 / 4                             |
| Air Side/Gas Side Seal Oil Temperature   | 130 / 125                         |
| Hydrogen Dew Point / Hydrogen Purity   | -29.4 / 97.7                      |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.5 / 85.4                       |
| Flyash Blower Pressure North/South   | 4 / 5                             |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 137410                            |
| Supplemental Precip Flyash Blower Discharge Pressure   | 11                                |
| Supplemental Precip Flyash Hoppers in Bypass   | 0                                 |
| Kaydon System Pressure / Water Meter Reading   | 0 / 482                           |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | level rises 2.3in. above setpoint |
| TA-6040 Discharge pressure/Oil temperature   | 254 / 132                         |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 86       |          |           |          |          |        |
| T24 | 110      |          |           |          |          |        |
| ST2 | 60       | 60       | +         | 2        |          |        |
| RT2 | X1- 70   | 70       | +         | 1        | 400      |        |
|     | X2- 70   |          |           |          |          |        |
| MT2 | 70       | 75       | +         | 2.5      | 1600     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |      |
|---|---|----|------|
| Circulators in operation                                    | 2A  | 2B | Both |
| Screen house Recirc valve position                          |   |    | %    |
| Forebay Frozen?   | YES   | NO |      |
| Is there evidence of Deicing water being released to river? | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |

NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service.

power spray- 6700  
SCR-2177  
SBAC- 83663

Date: 7/17/24

Shift: \_\_\_\_\_

Name: \_\_\_\_\_

Unit 2

|  |              |
|--|--------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65+60 / Both |
| Heat Exchanger Parallel Operation North and South  |              |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 110 / 112    |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 102 / 100    |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | -2 / 10      |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 6 / 7        |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 70 / 80      |
| 2B DA Pump Discharge Pressure  | 3.5          |
| 2B DA Pump Bearing Lube Oil Pressure   | 3.5          |
| 2A DA Pump Discharge Pressure  | 2.5          |
| 2A DA Pump Bearing Lube Oil Pressure   | 1            |
| MBFP/SUBFP Gland Water Pressure  | 230          |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 / 150     |
| Coupling Oil Temperature   | 130          |
| Turbine Oil Temperature  | 130          |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 3            |
| Condenser Inlet Temperature  | 80           |
| Condenser Outlet Temperature East / West   | 100 / 100    |
| Condenser Inlet Pressure East / West   | 4 / 4        |
| Air Side/Gas Side Seal Oil Temperature   | 125 / 125    |
| Hydrogen Dew Point / Hydrogen Purity   | -10.5 / 97.5 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.7 / 81.5  |
| Flyash Blower Pressure North/South   | 4 / 5        |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 137.7 / 110  |
| Supplemental Precip Flyash Blower Discharge Pressure   | 10           |
| Supplemental Precip Flyash Hoppers in Bypass   | 0            |
| Kaydon System Pressure / Water Meter Reading   | 0 / 1482     |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓            |
| TA-6040 Discharge pressure/Oil temperature   | 263 / 180    |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 87       |          |           |          |          |        |
| T24 | 75       |          |           |          |          |        |
| ST2 | 60       | 55       | +         | 2        |          |        |
| RT2 | X1-70    | 65       | +         | 1.5      | 400      |        |
|     | X2-70    |          |           |          |          |        |
| MT2 | 70       | 60       | +         | 2.5      | 400      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| Circulators in operation                                    | River Info  |    | Both     |
|---|---|----|----------|
|   | 2A  | 2B |          |
| Screen house Recirc valve position                          |   |    | % closed |
| Forebay Frozen?   | YES   | NO |          |
| Is there evidence of Deicing water being released to river? | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO       |

NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service.

power spray-6732  
SCR-2180  
SBAC-83988



Date: 7/19/24

Shift: day

Name: Jade

Unit 2

|  |              |       |
|--|--------------|-------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 55           | 12A   |
| Heat Exchanger Parallel Operation North and South  |              |       |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 80           | 80    |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 82           | 84    |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 0            | -3    |
| Air In-leakage @ 2A / 2B Vacuum Pumps  |              | /     |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   |              | /     |
| 2B DA Pump Discharge Pressure  | 3            |       |
| 2B DA Pump Bearing Lube Oil Pressure   |              |       |
| 2A DA Pump Discharge Pressure  | 3            |       |
| 2A DA Pump Bearing Lube Oil Pressure   |              |       |
| MBFP/SUBFP Gland Water Pressure  |              |       |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10           | 130   |
| Coupling Oil Temperature   |              |       |
| Turbine Oil Temperature  |              |       |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 3            |       |
| Condenser Inlet Temperature  | 74           |       |
| Condenser Outlet Temperature East / West   | 80           | 80    |
| Condenser Inlet Pressure East / West   | 4            | 4     |
| Air Side/Gas Side Seal Oil Temperature   |              | /     |
| Hydrogen Dew Point / Hydrogen Purity   | -44.4        | 97.7  |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 50.8         | 10    |
| Flyash Blower Pressure North/South   | 3.5          | 14.7  |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 1,3,6,7,9,10 |       |
| Supplemental Precip Flyash Blower Discharge Pressure   | 10           |       |
| Supplemental Precip Flyash Hoppers in Bypass   | 8            |       |
| Kaydon System Pressure / Water Meter Reading   | 8            | 14172 |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. |              | ✓     |
| TA-6040 Discharge pressure/Oil temperature   |              | 199   |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 12       |          |           |          |          |        |
| T24 | 84       |          |           |          |          |        |
| ST2 | 55       | 50       | +         | 1        |          |        |
| RT2 | X1- 25   | 25       | -         | 1        | 190      |        |
|     | X2- 25   |          |           |          |          |        |
| MT2 | 45       | 45       | +         | 1        | 1600     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |      |
|---|---|----|------|
|   | 2A  | 2B |      |
| Circulators in operation                                    |   |    | Both |
| Screen house Recirc valve position                          |   |    | %    |
| Forebay Frozen?   | YES   | NO |      |
| Is there evidence of Deicing water being released to river? | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |

NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service.

Date: 08/02/24

Shift: night

Name: Croissant

Unit 2

|  |                   |
|--|-------------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 50 / 26           |
| Heat Exchanger Parallel Operation North and South  |                   |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 100 / 102         |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 95 / 99           |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | -5 / -14          |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 10 / 8            |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 110 / 110         |
| 2B DA Pump Discharge Pressure  | 3                 |
| 2B DA Pump Bearing Lube Oil Pressure   | 2.5               |
| 2A DA Pump Discharge Pressure  | 2.5               |
| 2A DA Pump Bearing Lube Oil Pressure   | 5                 |
| MBFP/SUBFP Gland Water Pressure  | 260               |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 / 160          |
| Coupling Oil Temperature   | 125               |
| Turbine Oil Temperature  | 125               |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 5                 |
| Condenser Inlet Temperature  | 78                |
| Condenser Outlet Temperature East / West   | 104 / 102         |
| Condenser Inlet Pressure East / West   | 4 / 4             |
| Air Side/Gas Side Seal Oil Temperature   | 125 / 120         |
| Hydrogen Dew Point / Hydrogen Purity   | -30.9 / 98.4      |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 49.6 / 73.2       |
| Flyash Blower Pressure North/South   | 5 / 6             |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 1, 3, 6, 7, 9, 10 |
| Supplemental Precip Flyash Blower Discharge Pressure   | 0                 |
| Supplemental Precip Flyash Hoppers in Bypass   | 0                 |
| Kaydon System Pressure / Water Meter Reading   | 0 / 4182          |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓                 |
| TA-6040 Discharge pressure/Oil temperature   | 1.1 / 106         |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 96       |          |           |          |          |        |
| T24 | 107      |          |           |          |          |        |
| ST2 | 55       | 55       | +         | 2.5      |          |        |
| RT2 | X1-50    | 55       | +         | 4        | 1800     | 1600   |
|     | X2-62    |          |           |          |          |        |
| MT2 | 70       | 60       | +         | 3.5      | 1500     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |        |      |
|---|---|--------|------|
| Circulators in operation                                    | 2A  | 2B     | Both |
| Screen house Recirc valve position                          |   | closed | %    |
| Forebay Frozen?   | YES   | NO     |      |
| Is there evidence of Deicing water being released to river? | If YES close off on the Screen house Recirc valve until there is no flow. |        | NO   |

NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service.

power-6775  
 SUR: 2181  
 SBAC-84049



Date: 8/6/24

Shift: \_\_\_\_\_

Name: \_\_\_\_\_

Unit 2

|  |             |
|--|-------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 62 130H     |
| Heat Exchanger Parallel Operation North and South  |             |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 102 1104    |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 94 196      |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 48 150      |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 3 10        |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 90 190      |
| 2B DA Pump Discharge Pressure  | 430         |
| 2B DA Pump Bearing Lube Oil Pressure   | 2.5         |
| 2A DA Pump Discharge Pressure  | 400         |
| 2A DA Pump Bearing Lube Oil Pressure   | 2.5         |
| MBFP/SUBFP Gland Water Pressure  | 300         |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 1/60     |
| Coupling Oil Temperature   | 125         |
| Turbine Oil Temperature  | 125         |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 3           |
| Condenser Inlet Temperature  | 74          |
| Condenser Outlet Temperature East / West   | 98 196      |
| Condenser Inlet Pressure East / West   | 4 14.5      |
| Air Side/Gas Side Seal Oil Temperature   | 125 118     |
| Hydrogen Dew Point / Hydrogen Purity   | -40.7 198.1 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.7 1872   |
| Flyash Blower Pressure North/South   | 4.6 14.2    |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 7,10,3      |
| Supplemental Precip Flyash Blower Discharge Pressure   | 2.8         |
| Supplemental Precip Flyash Hoppers in Bypass   | NONE        |
| Kaydon System Pressure / Water Meter Reading   | 56 14/82    |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ok          |
| TA-6040 Discharge pressure/Oil temperature   | 248 1126    |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 76       |          |           |          |          |        |
| T24 | 103      |          |           |          |          |        |
| ST2 | 50       | 50       | +         | 1.5      |          |        |
| RT2 | X1- 65   | 100      | +         | 1        | 1750     |        |
|     | X2- 65   |          |           |          |          |        |
| MT2 | 70       | 78       | +         | 3.5      | 1500     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |      |
|---|---|----|------|
|   | 2A  | 2B |      |
| Circulators in operation                                    |   |    | Both |
| Screen house Recirc valve position                          |   | 0  | %    |
| Forebay Frozen?   | YES   | NO |      |
| Is there evidence of Deicing water being released to river? | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |

NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service.

Date: 11-26-24

Shift: D

Name: MB

Unit 2

|  |   |
|--|---|
| Cooling Water Pump Discharge Pressure / Pumps in service   | / |
| Heat Exchanger Parallel Operation North and South  |   |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | / |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | / |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | / |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | / |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | / |
| 2B DA Pump Discharge Pressure  |   |
| 2B DA Pump Bearing Lube Oil Pressure   |   |
| 2A DA Pump Discharge Pressure  |   |
| 2A DA Pump Bearing Lube Oil Pressure   |   |
| MBFP/SUBFP Gland Water Pressure  |   |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | / |
| Coupling Oil Temperature   |   |
| Turbine Oil Temperature  |   |
| Turbine Oil Vapor Extractor Vacuum "H2O  |   |
| Condenser Inlet Temperature  |   |
| Condenser Outlet Temperature East / West   | / |
| Condenser Inlet Pressure East / West   | / |
| Air Side/Gas Side Seal Oil Temperature   | / |
| Hydrogen Dew Point / Hydrogen Purity   | / |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | / |
| Flyash Blower Pressure North/South   | / |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   |   |
| Supplemental Precip Flyash Blower Discharge Pressure   |   |
| Supplemental Precip Flyash Hoppers in Bypass   |   |
| Kaydon System Pressure / Water Meter Reading   | / |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. |   |
| TA-6040 Discharge pressure/Oil temperature   | / |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX |          |          |           |          |          |        |
| T24 |          |          |           |          |          |        |
| ST2 |          |          |           |          |          |        |
| RT2 | X1-      |          |           |          |          |        |
|     | X2-      |          |           |          |          |        |
| MT2 |          |          |           |          |          |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |      |
|---|---|----|------|
| Circulators in operation  | 2A  | 2B | Both |
| Screen house Recirc valve position  |   |    | %    |
| Forebay Frozen?   | YES   | NO |      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |    |      |

Date: 11-27-24

Shift: D

Name: AT

Unit 2

|   |              |
|---|--------------|
| Cooling Water Pump Discharge Pressure / Pumps in service  | 65 1 2A      |
| Heat Exchanger Parallel Operation North and South   |              |
| Cooling Water Heat Exchanger Inlet Temperature North / South  | 68 1 68      |
| Cooling Water Heat Exchanger Outlet Temperature North / South   | 56 1 60      |
| Cooling Water Heat Exchanger Discharge Pressure North / South   | 55 1 55      |
| Air In-leakage @ 2A / 2B Vacuum Pumps   | 12 1 14      |
| Seal Water Temp @ 2A and 2B Vacuum Pumps  | 68 1 58      |
| 2B DA Pump Discharge Pressure   | 400          |
| 2B DA Pump Bearing Lube Oil Pressure  | 4.5          |
| 2A DA Pump Discharge Pressure   | 440          |
| 2A DA Pump Bearing Lube Oil Pressure  | 2.5          |
| MBFP/SUBFP Gland Water Pressure   | 325          |
| Coupling Oil Pump Suction Pressure/Discharge Pressure   | 10 1 100     |
| Coupling Oil Temperature  | 110          |
| Turbine Oil Temperature   | 100          |
| Turbine Oil Vapor Extractor Vacuum "H2O   |              |
| Condenser Inlet Temperature   | 42           |
| Condenser Outlet Temperature East / West  | 51 1 57      |
| Condenser Inlet Pressure East / West  | 4 1 4        |
| Air Side/Gas Side Seal Oil Temperature  | 102 1 95     |
| Hydrogen Dew Point / Hydrogen Purity  | -103.8 1 100 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure   | 59.2 1 74.1  |
| Flyash Blower Pressure North/South  | 6.1 1 8.0    |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass  | 4.7          |
| Supplemental Precip Flyash Blower Discharge Pressure  | 3.2          |
| Supplemental Precip Flyash Hoppers in Bypass  | 7            |
| Kaydon System Pressure / Water Metering   | 6 1 4215     |
| All slag sluice handling equipment for Unit 2 has been inspected for proper operation and discrepancies have been reported. | OK           |
| TA-6040 Discharge pressure/Oil temperature  | 150.2 1 118  |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 52       |          |           |          |          |        |
| T24 | 107      |          |           |          |          |        |
| ST2 | 35       | 35       | =         | 1        |          |        |
| RT2 | X1- 45   | 40       | =         | 3        | 400      | -      |
|     | X2- 45   |          |           |          |          |        |
| MT2 | 60       | 60       | +         | 4.5      | 1000     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |      |
|---|---|----|------|
| Circulators in operation                                    | 2A  | 2B | Both |
| Screen house Recirc valve position                          |   |    | %    |
| Forebay Frozen?   | YES   | NO |      |
| If there evidence of Deicing water being released to river? | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |

NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service.



Date: 27 NOV 24

Shift: N

Name: ROWELL

Unit 2

|  |                 |                 |
|--|-----------------|-----------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65              | 12A             |
| Heat Exchanger Parallel Operation  | North and South |                 |
| Cooling Water Heat Exchanger Inlet Temperature   | North / South   | 65 156 20       |
| Cooling Water Heat Exchanger Outlet Temperature  | North / South   | 56 160          |
| Cooling Water Heat Exchanger Discharge Pressure  | North / South   | 55 160          |
| Air In-leakage @ 2A / 2B Vacuum Pumps  |                 | 15 115          |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   |                 | 50 150          |
| 2B DA Pump Discharge Pressure  |                 | 410             |
| 2B DA Pump Bearing Lube Oil Pressure   |                 | 4.5             |
| 2A DA Pump Discharge Pressure  |                 | 450             |
| 2A DA Pump Bearing Lube Oil Pressure   |                 | 3               |
| MBFP/SUBFP Gland Water Pressure  |                 | 300             |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  |                 | 10 1170         |
| Coupling Oil Temperature   |                 | 110             |
| Turbine Oil Temperature  |                 | 100             |
| Turbine Oil Vapor Extractor Vacuum "H2O  |                 | 3               |
| Condenser Inlet Temperature  |                 | 40              |
| Condenser Outlet Temperature East / West   |                 | 4 14            |
| Condenser Inlet Pressure East / West   |                 | -4 14           |
| Air Side/Gas Side Seal Oil Temperature   |                 | 105 195         |
| Hydrogen Dew Point / Hydrogen Purity   |                 | -87.3 1100      |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  |                 | 59.2 174.5      |
| Flyash Blower Pressure North/South   |                 | 5 14.4          |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   |                 | No. 02 / 37 110 |
| Supplemental Precip Flyash Blower Discharge Pressure   |                 | 3.4             |
| Supplemental Precip Flyash Hoppers in Bypass   |                 | NONE            |
| Kaydon System Pressure / Water Meter Reading   |                 | 0 14210         |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. |                 | YES             |
| TA-6040 Discharge pressure/Oil temperature   |                 | 195.4 1118.3    |

TRANSFORMERS

|     | WDG TEMP   | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|------------|----------|-----------|----------|----------|--------|
| 2TX | 56         |          |           |          |          |        |
| T24 | No READING |          |           |          |          |        |
| ST2 | 35         | 35       | -         | 0        |          |        |
| RT2 | X1- 45     | 40       | -         | 1        | 500      |        |
|     | X2- 45     |          |           |          |          |        |
| MT2 | 85 60      | 65       | +         | 3.5      | 1000     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    | Both |
|---|---|----|------|
|   | 2A  | 2B |      |
| Circulators in operation                                    |   |    | Both |
| Screen house Recirc valve position                          |   |    | %    |
| Forebay Frozen?   | YES   | NO |      |
| Is there evidence of Deicing water being released to river? | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |

NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service.



Date: 11-25-24

Shift: D

Name: MB

Unit 2

|  |                     |
|--|---------------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65 / 2A             |
| Heat Exchanger Parallel Operation North and South  |                     |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 70 / 70             |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 60 / 55             |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55 / 55             |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 1                   |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 50 / 50             |
| 2B DA Pump Discharge Pressure  | 4                   |
| 2B DA Pump Bearing Lube Oil Pressure   | ✓                   |
| 2A DA Pump Discharge Pressure  | 3                   |
| 2A DA Pump Bearing Lube Oil Pressure   | ✓                   |
| MBFP/SUBFP Gland Water Pressure  | 325                 |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 / 170            |
| Coupling Oil Temperature   | 110                 |
| Turbine Oil Temperature  | 90                  |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 100                 |
| Condenser Inlet Temperature  | 40                  |
| Condenser Outlet Temperature East / West   | 60 / 50             |
| Condenser Inlet Pressure East / West   | 4 / 4               |
| Air Side/Gas Side Seal Oil Temperature   | 100 / 118           |
| Hydrogen Dew Point / Hydrogen Purity   | -90.7 / 14.4        |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.3 5.3 / 5.7 14.7 |
| Flyash Blower Pressure North/South   | 5.3 / 5.7           |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 3, 6, 7, 8, 9, 10   |
| Supplemental Precip Flyash Blower Discharge Pressure   | 4.1                 |
| Supplemental Precip Flyash Hoppers in Bypass   | —                   |
| Kaydon System Pressure / Water Meter Reading   | LS 14210            |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓                   |
| TA-6040 Discharge pressure/Oil temperature   | 1                   |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX |          |          |           |          |          |        |
| T24 | 40       |          |           |          |          |        |
| ST2 | 50       | 35       | —         | 1        |          |        |
| RT2 | X1- 50   | 40       | 25        | 1        | 400      | —      |
|     | X2- 50   |          |           |          |          |        |
| MT2 | 50       | 50       | 25        | 2        | 1000     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   |  | River Info  |    |        |
|---|--|---|----|--------|
|   |  | 2A  | 2B | (Both) |
| Circulators in operation  |  |   |    |        |
| Screen house Recirc valve position  |  |   |    | 0 %    |
| Forebay Frozen?   |  | YES   | NO |        |
| Is there evidence of Deicing water being released to river?   |  | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO     |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |  |   |    |        |

Date: 11-29-24

Shift: N

Name: AP

Unit 2

|  |              |
|--|--------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65 1 2A      |
| Heat Exchanger Parallel Operation North and South  |              |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 68 1 69      |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 56 1 58      |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55 1 55      |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 12 1 12      |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 51 1 51      |
| 2B DA Pump Discharge Pressure  | 450          |
| 2B DA Pump Bearing Lube Oil Pressure   | 2            |
| 2A DA Pump Discharge Pressure  | 410          |
| 2A DA Pump Bearing Lube Oil Pressure   | 4.5          |
| MBFP/SUBFP Gland Water Pressure  | 250          |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 1 168     |
| Coupling Oil Temperature   | 110          |
| Turbine Oil Temperature  | 100          |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2.5          |
| Condenser Inlet Temperature  | 41           |
| Condenser Outlet Temperature East / West   | 57 1 51      |
| Condenser Inlet Pressure East / West   | 4 1 4        |
| Air Side/Gas Side Seal Oil Temperature   | 104 1 96     |
| Hydrogen Dew Point / Hydrogen Purity   | -87.5 1 99.7 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 60.4 1 76.4  |
| Flyash Blower Pressure North/South   | 4.4 1 4.7    |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 3.6, 7.9, 10 |
| Supplemental Precip Flyash Blower Discharge Pressure   | 3.5          |
| Supplemental Precip Flyash Hoppers in Bypass   |              |
| Kaydon System Pressure / Water Meter Reading   | 0 1 4215     |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | OK           |
| TA-6040 Discharge pressure/Oil temperature   | 128.8 1 17   |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 55       |          |           |          |          |        |
| T24 |          |          |           |          |          |        |
| ST2 | 35       | 35       | -         | 1        |          |        |
| RT2 | X1- 50   | 40       | +         | 1        | 400      |        |
|     | X2- 50   |          |           |          |          |        |
| MT2 | 60       | 60       | +         | 3.5      | 950      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   |  | River Info  |    |      |
|---|--|---|----|------|
|   |  | 2A  | 2B |      |
| Circulators in operation  |  |   |    | Both |
| Screen house Recirc valve position  |  |   | 0  | %    |
| Forebay Frozen?   |  | YES   | NO |      |
| Is there evidence of Deicing water being released to river?   |  | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |  |   |    |      |

EOD - EA

Date: 11/29/24

Shift: A Night

Name: Peri

Unit 2

|  |              |
|--|--------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65   2A      |
| Heat Exchanger Parallel Operation North and South  |              |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 70   70      |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 55   55      |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 70   70      |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 1            |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 50   50      |
| 2B DA Pump Discharge Pressure  | 275          |
| 2B DA Pump Bearing Lube Oil Pressure   | 4.5          |
| 2A DA Pump Discharge Pressure  | 140          |
| 2A DA Pump Bearing Lube Oil Pressure   | 2.5          |
| MBFP/SUBFP Gland Water Pressure  |              |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10   170°    |
| Coupling Oil Temperature   | 70°   110°   |
| Turbine Oil Temperature  | 110          |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2.5          |
| Condenser Inlet Temperature  |              |
| Condenser Outlet Temperature East / West   | - 10   - 10  |
| Condenser Inlet Pressure East / West   | 4   4        |
| Air Side/Gas Side Seal Oil Temperature   | 105°   110°  |
| Hydrogen Dew Point / Hydrogen Purity   | 79.71   99.8 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.6   74.8  |
| Flyash Blower Pressure North/South   | 4.5   4.5    |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   |              |
| Supplemental Precip Flyash Blower Discharge Pressure   |              |
| Supplemental Precip Flyash Hoppers in Bypass   |              |
| Kaydon System Pressure / Water Meter Reading   | 0   425.2    |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. |              |
| TA-6040 Discharge pressure/Oil temperature   | 138.4   117  |

TRANSFORMERS

|     | WDG TEMP         | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|------------------|----------|-----------|----------|----------|--------|
| 2TX | 056              |          |           |          |          |        |
| T24 | 80               |          |           |          |          |        |
| ST2 | 35               | 30       | -         | 0        |          |        |
| RT2 | X1- 45<br>X2- 45 | 40       | 25        | 1        | 400      | 0      |
| MT2 | 65               | 60       | pos       | 3        | 100      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |   |    |      |
|---|---|----|------|
| Circulators in operation  | 2A  | 2B | Both |
| Screen house Recirc valve position  |   |    | %    |
| Forebay Frozen?   | YES   | NO |      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |    |      |

Date: 11-30-24

Shift: N

Name: MB

Unit 2

|  |                     |
|--|---------------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65 / 12A            |
| Heat Exchanger Parallel Operation North and South  |                     |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 70 / 65             |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 60 / 55             |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55 / 55             |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 1                   |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 50 / 50             |
| 2B DA Pump Discharge Pressure  | 4.5                 |
| 2B DA Pump Bearing Lube Oil Pressure   | ✓                   |
| 2A DA Pump Discharge Pressure  | 2                   |
| 2A DA Pump Bearing Lube Oil Pressure   | ✓                   |
| MBFP/SUBFP Gland Water Pressure  | 250                 |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 / 170            |
| Coupling Oil Temperature   | 110                 |
| Turbine Oil Temperature  | 100                 |
| Turbine Oil Vapor Extractor Vacuum "H2O  |                     |
| Condenser Inlet Temperature  | 40                  |
| Condenser Outlet Temperature East / West   | 55 / 50             |
| Condenser Inlet Pressure East / West   | 4.3 / 4             |
| Air Side/Gas Side Seal Oil Temperature   | 100 / 100           |
| Hydrogen Dew Point / Hydrogen Purity   | -61.8 / 99.6        |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 60.6 / 11.2         |
| Flyash Blower Pressure North/South   | 4.8 / 100 / 100 4.9 |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 3,4,5,6,7           |
| Supplemental Precip Flyash Blower Discharge Pressure   | 4.1                 |
| Supplemental Precip Flyash Hoppers in Bypass   |                     |
| Kaydon System Pressure / Water Meter Reading   | <5 / 14210          |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓                   |
| TA-6040 Discharge pressure/Oil temperature   | 141 / 117           |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX |          |          |           |          |          |        |
| T24 |          |          |           |          |          |        |
| ST2 |          |          |           |          |          |        |
| RT2 | X1-      |          |           |          |          |        |
|     | X2-      |          |           |          |          |        |
| MT2 |          |          |           |          |          |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   |   | River Info |     |        |
|---|---|------------|-----|--------|
| Circulators in operation  | 2A  | 2B         |     | (Both) |
| Screen house Recirc valve position  |   |            | 0 % |        |
| Forebay Frozen?   | YES   | NO         |     |        |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |            |     | NO     |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |            |     |        |

EOD - EA

Date: 12/2/04

Shift: \_\_\_\_\_

Name: \_\_\_\_\_

Unit 2

|  |             |
|--|-------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 1           |
| Heat Exchanger Parallel Operation North and South  |             |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 68 / 68     |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 56 / 56     |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55 / 60     |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 10 / 10     |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 50 / 50     |
| 2B DA Pump Discharge Pressure  | 400         |
| 2B DA Pump Bearing Lube Oil Pressure   | 4.5         |
| 2A DA Pump Discharge Pressure  | 450         |
| 2A DA Pump Bearing Lube Oil Pressure   | 3           |
| MBFP/SUBFP Gland Water Pressure  | 250         |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 / 166    |
| Coupling Oil Temperature   | 110         |
| Turbine Oil Temperature  | 105         |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2.2         |
| Condenser Inlet Temperature  | 45          |
| Condenser Outlet Temperature East / West   | 55 / 55     |
| Condenser Inlet Pressure East / West   | 3.5 / 3.5   |
| Air Side/Gas Side Seal Oil Temperature   | 100 / 98    |
| Hydrogen Dew Point / Hydrogen Purity   | -29 / 99    |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 60.8 / 77.9 |
| Flyash Blower Pressure North/South   | 4.2 / 15.0  |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   |             |
| Supplemental Precip Flyash Blower Discharge Pressure   | 4.5         |
| Supplemental Precip Flyash Hoppers in Bypass   |             |
| Kaydon System Pressure / Water Meter Reading   | 2 / 423     |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. |             |
| TA-6040 Discharge pressure/Oil temperature   | 142.7 / 117 |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 51       |          |           |          |          |        |
| T24 |          |          |           |          |          |        |
| ST2 | 35       | 35       | -         | 0        |          |        |
| RT2 | X1- 42   | 38       | -         | 1        | 300      |        |
|     | X2- 42   |          |           |          |          |        |
| MT2 | 65       | 60       | +         | 3        | 900      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   |   | River Info |    |      |
|---|---|------------|----|------|
|   |   | 2A         | 2B | Both |
| Circulators in operation  |   |            |    |      |
| Screen house Recirc valve position  |   |            |    | %    |
| Forebay Frozen?   | YES   |            | NO |      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |            |    | NO   |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |            |    |      |



Date: 12-3-04

Shift: \_\_\_\_\_

Name: \_\_\_\_\_

Unit 2

|  |             |
|--|-------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65 12A      |
| Heat Exchanger Parallel Operation North and South  |             |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 70 70       |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 55 55       |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55 50       |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 7 16        |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 65 12A      |
| 2B DA Pump Discharge Pressure  | 425         |
| 2B DA Pump Bearing Lube Oil Pressure   | 4.5         |
| 2A DA Pump Discharge Pressure  | 125         |
| 2A DA Pump Bearing Lube Oil Pressure   | 3           |
| MBFP/SUBFP Gland Water Pressure  | 35          |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 1168     |
| Coupling Oil Temperature   | 110°F       |
| Turbine Oil Temperature  | 100°F       |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2.5         |
| Condenser Inlet Temperature  | 58°F        |
| Condenser Outlet Temperature East / West   | 1           |
| Condenser Inlet Pressure East / West   | 90 1 50     |
| Air Side/Gas Side Seal Oil Temperature   | 102 98      |
| Hydrogen Dew Point / Hydrogen Purity   | -67.51 99.4 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 60.4 177.6  |
| Flyash Blower Pressure North/South   | 0.4 91 05.8 |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   |             |
| Supplemental Precip Flyash Blower Discharge Pressure   | 06 8 - 04.8 |
| Supplemental Precip Flyash Hoppers in Bypass   |             |
| Kaydon System Pressure / Water Meter Reading   | 0 14276.5   |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | 4.5         |
| TA-6040 Discharge pressure/Oil temperature   | 156.11 00   |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 0.57     |          |           |          |          |        |
| T24 | 80       |          |           |          |          |        |
| ST2 | 40       | 40       | 25        | 1        |          |        |
| RT2 | X1- 50   | 40       | 25        | 1        | 300      | 0      |
|     | X2- 50   |          |           |          |          |        |
| MT2 | 70       | 60       | 30        | 3        | 1000     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |  |
|---|--|
| Circulators in operation  | 2A 2B Both   |
| Screen house Recirc valve position  | NO 2% %  |
| Forebay Frozen?   | YES NO   |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. NO |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |  |

Date: 12/31/24

Shift: N

Name: PETIAS

Unit 2

|  |               |
|--|---------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 2A / 64       |
| Heat Exchanger Parallel Operation North and South  |               |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 70 / 70       |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 60 / 57       |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 58 / 60       |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | +             |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 50 / 50       |
| 2B DA Pump Discharge Pressure  | 425           |
| 2B DA Pump Bearing Lube Oil Pressure   | 4.5           |
| 2A DA Pump Discharge Pressure  | 420           |
| 2A DA Pump Bearing Lube Oil Pressure   | 2.5           |
| MBFP/SUBFP Gland Water Pressure  | 240           |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 / 170      |
| Coupling Oil Temperature   | 90            |
| Turbine Oil Temperature  | 108           |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2             |
| Condenser Inlet Temperature  | 38            |
| Condenser Outlet Temperature East / West   | 52 / 52       |
| Condenser Inlet Pressure East / West   | 4 / 4         |
| Air Side/Gas Side Seal Oil Temperature   | 105 / 100     |
| Hydrogen Dew Point / Hydrogen Purity   | 59.3 / 99     |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 61 / 28.7     |
| Flyash Blower Pressure North/South   | 5.1 / 3.6     |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 3, 4, 5, 6, 7 |
| Supplemental Precip Flyash Blower Discharge Pressure   | 6.8           |
| Supplemental Precip Flyash Hoppers in Bypass   | 0             |
| Kaydon System Pressure / Water Meter Reading   | 0 / 14230     |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. |               |
| TA-6040 Discharge pressure/Oil temperature   | 1             |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX |          |          |           |          |          |        |
| T24 | 085      |          |           |          |          |        |
| ST2 | 40       | 38       | 25        | 0        |          |        |
| RT2 | X1- 50   | 40       | 25        | 0        | 250      |        |
|     | X2- 50   |          |           |          |          |        |
| MT2 | 60       | 60       | 25        | 2        | 1100     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |  |           |
|---|--|-----------|
| Circulators in operation  | (2A)   | (2B) Both |
| Screen house Recirc valve position  |  | % 0       |
| Forebay Frozen?   | YES  | (NO)      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. NO |           |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |  |           |

Date: 12/5/24

Shift: D

Name: \_\_\_\_\_

Unit 2

|  |              |
|--|--------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65 / 2A      |
| Heat Exchanger Parallel Operation North and South  |              |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 64 / 64      |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 55 / 58      |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 58 / 54      |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 7 / 6        |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 50 / 50      |
| 2B DA Pump Discharge Pressure  | 410          |
| 2B DA Pump Bearing Lube Oil Pressure   | 4.5          |
| 2A DA Pump Discharge Pressure  | 120          |
| 2A DA Pump Bearing Lube Oil Pressure   | 2            |
| MBFP/SUBFP Gland Water Pressure  | 30           |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 / 165     |
| Coupling Oil Temperature   | 110°F        |
| Turbine Oil Temperature  | 102°F        |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2            |
| Condenser Inlet Temperature  | 66°F         |
| Condenser Outlet Temperature East / West   | 40°F 52°F    |
| Condenser Inlet Pressure East / West   | 58 / 52      |
| Air Side/Gas Side Seal Oil Temperature   | 102 / 108    |
| Hydrogen Dew Point / Hydrogen Purity   | -56.6°F 99.2 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 100.11 78.9  |
| Flyash Blower Pressure North/South   | 0.07 / 04.5  |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | NO           |
| Supplemental Precip Flyash Blower Discharge Pressure   | 05.1         |
| Supplemental Precip Flyash Hoppers in Bypass   | NO           |
| Kaydon System Pressure / Water Meter Reading   | 0 / 4236.5   |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | Y            |
| TA-6040 Discharge pressure/Oil temperature   | 1.8 / 95°F   |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 0.59     |          |           |          |          |        |
| T24 | 80.      |          |           |          |          |        |
| ST2 | 40       | 40       | neg       | 1        |          |        |
| RT2 | X1- 42   | 39       | 25°       | 1        | 300      | 0      |
|     | X2- 42   |          |           |          |          |        |
| MT2 | 50       | 75       | 27        | 2        | 1        |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |  |
|---|--|
| Circulators in operation                                    | 2A 2B Both   |
| Screen house Recirc valve position                          | 0 %  |
| Forebay Frozen?   | YES NO   |
| Is there evidence of Deicing water being released to river? | If YES close off on the Screen house Recirc valve until there is no flow. NO |

NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service.

EOD - EA

Date: 12-5-24

Shift: N

Name: MCB

Unit 2

|  |                       |
|--|-----------------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65 12A                |
| Heat Exchanger Parallel Operation  | North and South       |
| Cooling Water Heat Exchanger Inlet Temperature   | North / South 65 / 65 |
| Cooling Water Heat Exchanger Outlet Temperature  | North / South 55 / 52 |
| Cooling Water Heat Exchanger Discharge Pressure  | North / South 55 / 55 |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | <del>50 / 50</del>    |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 50 / 50               |
| 2B DA Pump Discharge Pressure  | 4.5                   |
| 2B DA Pump Bearing Lube Oil Pressure   | ✓                     |
| 2A DA Pump Discharge Pressure  | 3                     |
| 2A DA Pump Bearing Lube Oil Pressure   | ✓                     |
| MBFP/SUBFP Gland Water Pressure  |                       |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 / 110              |
| Coupling Oil Temperature   | 110                   |
| Turbine Oil Temperature  | 110                   |
| Turbine Oil Vapor Extractor Vacuum "H2O  |                       |
| Condenser Inlet Temperature  | 40                    |
| Condenser Outlet Temperature East / West   | 60 / 50               |
| Condenser Inlet Pressure East / West   | 4 / 4                 |
| Air Side/Gas Side Seal Oil Temperature   | 100 / 110             |
| Hydrogen Dew Point / Hydrogen Purity   | -70.7 / 99.1          |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 6.3 / 79.5            |
| Flyash Blower Pressure North/South   | 4.5 / 6.1             |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 3, 6, 7, 8, 9, 10     |
| Supplemental Precip Flyash Blower Discharge Pressure   | 7.6                   |
| Supplemental Precip Flyash Hoppers in Bypass   |                       |
| Kaydon System Pressure / Water Meter Reading   | < 5 / 4230            |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓                     |
| TA-6040 Discharge pressure/Oil temperature   |                       |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX |          |          |           |          |          |        |
| T24 |          |          |           |          |          |        |
| ST2 | 40       | 30       | 25-       | 2        |          |        |
| RT2 | X1- 50   | 40       | 25        | 2        | 300      | -      |
|     | X2- 50   |          |           |          |          |        |
| MT2 | 70       | 76       | 25+       | 4        | 1000     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |      |
|---|---|----|------|
| Circulators in operation  | 2A  | 2B | Both |
| Screen house Recirc valve position  |   |    | 0 %  |
| Forebay Frozen?   | YES   | NO |      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |    |      |

PSM-6964.441 SCR-2281 SBAC-87752



Date: 12/1/24

Shift: D

Name: PETIPAS

Unit 2

|  |             |
|--|-------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | A. 1 01     |
| Heat Exchanger Parallel Operation North and South  |             |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 68 / 70     |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 57 / 56     |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 50 / 56     |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | - / -       |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 50 / 60     |
| 2B DA Pump Discharge Pressure  | 4.65        |
| 2B DA Pump Bearing Lube Oil Pressure   | 4.5         |
| 2A DA Pump Discharge Pressure  | 4.30        |
| 2A DA Pump Bearing Lube Oil Pressure   | 2.5         |
| MBFP/SUBFP Gland Water Pressure  | 2.35        |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 / 170    |
| Coupling Oil Temperature   | 110         |
| Turbine Oil Temperature  | 108         |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2           |
| Condenser Inlet Temperature  | 40          |
| Condenser Outlet Temperature East / West   | 56 / 52     |
| Condenser Inlet Pressure East / West   | 4.5 / 4.5   |
| Air Side/Gas Side Seal Oil Temperature   | 105 / 110   |
| Hydrogen Dew Point / Hydrogen Purity   | 68.7 / 99.1 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.1 / 79.9 |
| Flyash Blower Pressure North/South   | 6.5 / 5.4   |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 34.5 / 6.7  |
| Supplemental Precip Flyash Blower Discharge Pressure   | 6.0         |
| Supplemental Precip Flyash Hoppers in Bypass   | 0           |
| Kaydon System Pressure / Water Meter Reading   | 0 / 4230    |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓           |
| TA-6040 Discharge pressure/Oil temperature   | off / off   |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 56       |          |           |          |          |        |
| T24 | 055      |          |           |          |          |        |
| ST2 | 4        | 38       | -         | 0        |          |        |
| RT2 | X1- 41   | 36       | -         | 1        | 300      |        |
|     | X2- 41   |          |           |          |          |        |
| MT2 | 20       | 60       | +         | -3       | 1000     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |  |
|---|--|
| Circulators in operation  | 2A 2B Both   |
| Screen house Recirc valve position  | % 0  |
| Forebay Frozen?   | YES NO   |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. NO |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |  |

TANK 2



Date: 12-6-24

Shift: N

Name: AP

Unit 2

|  |              |
|--|--------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65 12A       |
| Heat Exchanger Parallel Operation North and South  |              |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 68 169       |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 55 158       |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55 155       |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 8 17         |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 50 150       |
| 2B DA Pump Discharge Pressure  | 375          |
| 2B DA Pump Bearing Lube Oil Pressure   | 4.5          |
| 2A DA Pump Discharge Pressure  | 425          |
| 2A DA Pump Bearing Lube Oil Pressure   | 2            |
| MBFP/SUBFP Gland Water Pressure  | 250          |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 1170      |
| Coupling Oil Temperature   | 110          |
| Turbine Oil Temperature  | 100          |
| Turbine Oil Vapor Extractor Vacuum "H20  | 2.1          |
| Condenser Inlet Temperature  | 35           |
| Condenser Outlet Temperature East / West   | 56 152       |
| Condenser Inlet Pressure East / West   | 4 14         |
| Air Side/Gas Side Seal Oil Temperature   | 102 1105     |
| Hydrogen Dew Point / Hydrogen Purity   | 54.1 199.1   |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.6 180.2   |
| Flyash Blower Pressure North/South   | 4.5 14.4     |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 3.6, 7.9, 10 |
| Supplemental Precip Flyash Blower Discharge Pressure   | 7.5          |
| Supplemental Precip Flyash Hoppers in Bypass   |              |
| Kaydon System Pressure / Water Meter Reading   | 15 14236     |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | OK           |
| TA-6040 Discharge pressure/Oil temperature   | 250 117      |

88066

TRANSFORMERS

2285

0965

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 50       |          |           |          |          |        |
| T24 |          |          |           |          |          |        |
| ST2 | 35       | 30       | -         | .5       |          |        |
| RT2 | X1- 45   | 35       | -         | 1        | 300      |        |
|     | X2- 45   |          |           |          |          |        |
| MT2 | 60       | 50       | +         | 2.5      | 950      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |  |         |
|---|--|---------|
| Circulators in operation  | 2A   | 2B Both |
| Screen house Recirc valve position  |  | 0 %     |
| Forebay Frozen?   | YES  | NO      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. NO |         |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |  |         |

Date: 12-7

Shift: D

Name: Petryns

Unit 2

|  |             |
|--|-------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 2A / 66     |
| Heat Exchanger Parallel Operation North and South  |             |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 36 / 36     |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 37 / 37     |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 50 / 50     |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | - / -       |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | - / -       |
| 2B DA Pump Discharge Pressure  | -           |
| 2B DA Pump Bearing Lube Oil Pressure   | 3.5         |
| 2A DA Pump Discharge Pressure  | -           |
| 2A DA Pump Bearing Lube Oil Pressure   | 3           |
| MBFP/SUBFP Gland Water Pressure  | -           |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 / 40     |
| Coupling Oil Temperature   | -           |
| Turbine Oil Temperature  | 108         |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2           |
| Condenser Inlet Temperature  |             |
| Condenser Outlet Temperature East / West   | 32 / 33     |
| Condenser Inlet Pressure East / West   | 1 / 1       |
| Air Side/Gas Side Seal Oil Temperature   | 70 / 70     |
| Hydrogen Dew Point / Hydrogen Purity   | 81.5 / 99.1 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 45.4 / .03  |
| Flyash Blower Pressure North/South   | - / -       |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | -           |
| Supplemental Precip Flyash Blower Discharge Pressure   | -           |
| Supplemental Precip Flyash Hoppers in Bypass   | -           |
| Kaydon System Pressure / Water Meter Reading   | 0 / 4230    |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓           |
| TA-6040 Discharge pressure/Oil temperature   | 1           |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 48       |          |           |          |          |        |
| T24 |          |          |           |          |          |        |
| ST2 | 30       | 30       | -         | 0        |          |        |
| RT2 | X1- 35   | 35       | -         | 1        | 300      |        |
|     | X2- 35   |          |           |          |          |        |
| MT2 | 45       | 40       | -         | 1.5      | Lecc     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |   |    |
|---|---|----|
| Circulators in operation  | 2A  | 2B |
| Screen house Recirc valve position  |   | %  |
| Forebay Frozen?   | YES   | NO |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |    |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |    |

Date: 12-7-04

Shift: \_\_\_\_\_

Name: \_\_\_\_\_

Unit 2

|  |             |
|--|-------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | A 1 64      |
| Heat Exchanger Parallel Operation North and South  |             |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 64 1 65     |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 56 1 56     |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 46 1 50     |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | - 1 -       |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 58 1 50     |
| 2B DA Pump Discharge Pressure  | 450         |
| 2B DA Pump Bearing Lube Oil Pressure   | 4.5         |
| 2A DA Pump Discharge Pressure  | 430         |
| 2A DA Pump Bearing Lube Oil Pressure   | 3           |
| MBFP/SUBFP Gland Water Pressure  | 240         |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 16 1 168    |
| Coupling Oil Temperature   | 110         |
| Turbine Oil Temperature  | 108         |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2           |
| Condenser Inlet Temperature  |             |
| Condenser Outlet Temperature East / West   | 54 1 53     |
| Condenser Inlet Pressure East / West   | 36 1 34     |
| Air Side/Gas Side Seal Oil Temperature   | 105 1 100   |
| Hydrogen Dew Point / Hydrogen Purity   | 055- 1 99.9 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.5 1 80.0 |
| Flyash Blower Pressure North/South   | 6.5 1 5.3   |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 4 5 6 7     |
| Supplemental Precip Flyash Blower Discharge Pressure   | 8.0         |
| Supplemental Precip Flyash Hoppers in Bypass   | 0           |
| Kaydon System Pressure / Water Meter Reading   | 0 1 4230    |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓           |
| TA-6040 Discharge pressure/Oil temperature   | - 1 -       |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 51       |          |           |          |          |        |
| T24 |          |          |           |          |          |        |
| ST2 | 40       | 40       | -         | 0        |          |        |
| RT2 | X1- 43   | 32       | -         | 1.5      | 300      |        |
|     | X2- 42   |          |           |          |          |        |
| MT2 | 60       | 65       | +         | 1.       | 1000     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |      |
|---|---|----|------|
|   | 2A  | 2B | Both |
| Circulators in operation  |   |    |      |
| Screen house Recirc valve position  |   |    | % 20 |
| Forebay Frozen?   | YES   | NO |      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |    |      |



Date: 12-7-24

Shift: N

Name: MB

Unit 2

|  |                    |
|--|--------------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65 / 2A            |
| Heat Exchanger Parallel Operation North and South  |                    |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 70 / 70            |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 60 / 60            |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55 / 55            |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 1                  |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 50 / 50            |
| 2B DA Pump Discharge Pressure  | <del>375</del> 4.5 |
| 2B DA Pump Bearing Lube Oil Pressure   | 42.5               |
| 2A DA Pump Discharge Pressure  | 3                  |
| 2A DA Pump Bearing Lube Oil Pressure   | 22.5               |
| MBFP/SUBFP Gland Water Pressure  | 10 / 160           |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 110                |
| Coupling Oil Temperature   | 110                |
| Turbine Oil Temperature  |                    |
| Turbine Oil Vapor Extractor Vacuum "H2O  | -                  |
| Condenser Inlet Temperature  |                    |
| Condenser Outlet Temperature East / West   | <del>30</del> 140  |
| Condenser Inlet Pressure East / West   | 4 / 4              |
| Air Side/Gas Side Seal Oil Temperature   | 100 / 110          |
| Hydrogen Dew Point / Hydrogen Purity   | -61 / 99           |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 58.41 / 19.2       |
| Flyash Blower Pressure North/South   | 4.2 / 4.2          |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 3, 6, 7, 9, 10     |
| Supplemental Precip Flyash Blower Discharge Pressure   | 4.5                |
| Supplemental Precip Flyash Hoppers in Bypass   | -                  |
| Kaydon System Pressure / Water Meter Reading   | 1                  |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓                  |
| TA-6040 Discharge pressure/Oil temperature   | 254 / 1            |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX |          |          |           |          |          |        |
| T24 |          |          |           |          |          |        |
| ST2 | 40       | 110      | 25-       | 1        |          |        |
| RT2 | X1- 30   | 30       | 25-       | 2        | 2300     | 300    |
|     | X2- 30   |          |           |          |          |        |
| MT2 | 50       | 50       | 25+       | 2        | 1000     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |        |
|---|---|----|--------|
| Circulators in operation  | 2A  | 2B | (Both) |
| Screen house Recirc valve position  |   |    | 0%     |
| Forebay Frozen?   | YES   | NO |        |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO     |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |    |        |

PSM-6967.116 SCR-~~2291~~ SBAC-88479  
2291

Date: 12/8/24

Shift: D

Name: \_\_\_\_\_

Unit 2

|  |             |
|--|-------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | A / 68      |
| Heat Exchanger Parallel Operation North and South  |             |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 36 / 42     |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 47 / 36     |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 45 / 50     |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | - / -       |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | off / off   |
| 2B DA Pump Discharge Pressure  | -           |
| 2B DA Pump Bearing Lube Oil Pressure   | 4.5         |
| 2A DA Pump Discharge Pressure  | -           |
| 2A DA Pump Bearing Lube Oil Pressure   | 2.2         |
| MBFP/SUBFP Gland Water Pressure  | -           |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 60 / 135    |
| Coupling Oil Temperature   | OFF-LINE    |
| Turbine Oil Temperature  | 108         |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2           |
| Condenser Inlet Temperature  | 36          |
| Condenser Outlet Temperature East / West   | 32 / 32     |
| Condenser Inlet Pressure East / West   | 4.5 / 4.5   |
| Air Side/Gas Side Seal Oil Temperature   | 89 / 89     |
| Hydrogen Dew Point / Hydrogen Purity   | 78.6 / 99.1 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 51.7 / 0.3  |
| Flyash Blower Pressure North/South   | 4.01 / 3.8  |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 45 / 7      |
| Supplemental Precip Flyash Blower Discharge Pressure   | 4.0         |
| Supplemental Precip Flyash Hoppers in Bypass   | 0           |
| Kaydon System Pressure / Water Meter Reading   | 0 / 4230    |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓           |
| TA-6040 Discharge pressure/Oil temperature   | 1           |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE. | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|-----------|----------|--------|
| 2TX | 44       |          |           |           |          |        |
| T24 | 64       |          |           |           |          |        |
| ST2 | 45       | 40       | -         | 0         |          |        |
| RT2 | X1- 20   | 35       | -         | 1         | 300      |        |
|     | X2- 30   |          |           |           |          |        |
| MT2 | 50       | 50       | +         | 1.5       | 1000     |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |   |         |
|---|---|---------|
| Circulators in operation  | 2A  | 2B Both |
| Screen house Recirc valve position  |   | % 0     |
| Forebay Frozen?   | YES   | NO      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |         |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   | NO      |

Date: 12-8-24

Shift: N

Name: AP

Unit 2

|  |           |
|--|-----------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 70 124    |
| Heat Exchanger Parallel Operation North and South  |           |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 36 136    |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 37 138    |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 40 160    |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | - 1 -     |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | - 1 -     |
| 2B DA Pump Discharge Pressure  | -         |
| 2B DA Pump Bearing Lube Oil Pressure   | 2         |
| 2A DA Pump Discharge Pressure  | -         |
| 2A DA Pump Bearing Lube Oil Pressure   | 2         |
| MBFP/SUBFP Gland Water Pressure  | -         |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 1125   |
| Coupling Oil Temperature   | 95        |
| Turbine Oil Temperature  | 80        |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2.5       |
| Condenser Inlet Temperature  | 36        |
| Condenser Outlet Temperature East / West   | 36 136    |
| Condenser Inlet Pressure East / West   | 3.5 14    |
| Air Side/Gas Side Seal Oil Temperature   | 90 185    |
| Hydrogen Dew Point / Hydrogen Purity   | -85.81 99 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 49.6 10   |
| Flyash Blower Pressure North/South   | 4.1 14.2  |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   |           |
| Supplemental Precip Flyash Blower Discharge Pressure   | 3.6       |
| Supplemental Precip Flyash Hoppers in Bypass   | -         |
| Kaydon System Pressure / Water Meter Reading   | 20 13236  |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | OK        |
| TA-6040 Discharge pressure/Oil temperature   | 1.8 196   |

|     | 88469    | TRANSFORMERS | 2292      | 6967     |          |        |
|-----|----------|--------------|-----------|----------|----------|--------|
|     | WDG TEMP | OIL TEMP     | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
| 2TX | 48       |              |           |          |          |        |
| T24 | -        |              |           |          |          |        |
| ST2 | 2        | 50           | 40        | +        |          |        |
| RT2 | X1- 15   | 15           | -         | 1        | 2000     |        |
|     | X2- 15   |              |           |          |          |        |
| MT2 | 40       | 40           | +         | 1.5      | 950      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |   |    |
|---|---|----|
| Circulators in operation  | 2A  | 2B |
| Screen house Recirc valve position  | %   |    |
| Forebay Frozen?   | YES   | NO |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |    |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |    |



Date: 12-19-24

Shift: N

Name: AP

Unit 2

|  |              |
|--|--------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65 1 24      |
| Heat Exchanger Parallel Operation North and South  |              |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 70 1 74      |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 60 1 68      |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55 1 55      |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 17 1 16      |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 66 1 62      |
| 2B DA Pump Discharge Pressure  | 400          |
| 2B DA Pump Bearing Lube Oil Pressure   | 4.5          |
| 2A DA Pump Discharge Pressure  | 450          |
| 2A DA Pump Bearing Lube Oil Pressure   | 2.5          |
| MBFP/SUBFP Gland Water Pressure  | 300          |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 1 65      |
| Coupling Oil Temperature   | 110          |
| Turbine Oil Temperature  | 100          |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 3.1          |
| Condenser Inlet Temperature  | 36           |
| Condenser Outlet Temperature East / West   | 148          |
| Condenser Inlet Pressure East / West   | 4.5 1 4.5    |
| Air Side/Gas Side Seal Oil Temperature   | 115 1 115    |
| Hydrogen Dew Point / Hydrogen Purity   | -81.3 1 99.3 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.8 1 79.6  |
| Flyash Blower Pressure North/South   | 4.3 1 4.6    |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 4.7, 9.10    |
| Supplemental Precip Flyash Blower Discharge Pressure   | 4.7          |
| Supplemental Precip Flyash Hoppers in Bypass   |              |
| Kaydon System Pressure / Water Meter Reading   | 0 1 4260     |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | OK           |
| TA-6040 Discharge pressure/Oil temperature   | 253 1 117    |

| TRANSFORMERS |          |          |           |          |          |        |
|--------------|----------|----------|-----------|----------|----------|--------|
|              | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
| 2TX          | 55       |          |           |          |          |        |
| T24          |          |          |           |          |          |        |
| ST2          | 30       | 35       |           | 0        |          |        |
| RT2          | X1- 45   | 35       |           | 1        | 1650     |        |
|              | X2- 45   |          |           |          |          |        |
| MT2          | 60       | 60       | +         | 3.5      | 500      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |   |    |
|---|---|----|
|   | 2A  | 2B |
| Circulators in operation  |   |    |
| Screen house Recirc valve position  |   |    |
| Forebay Frozen?   | YES   | NO |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |    |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |    |

Date: 12/20/14

Shift: 0

Name: petipas

Unit 2

|  |                 |       |      |
|--|-----------------|-------|------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | B               | 1     | 57   |
| Heat Exchanger Parallel Operation  | North and South |       |      |
| Cooling Water Heat Exchanger Inlet Temperature   | North / South   | 36    | 36   |
| Cooling Water Heat Exchanger Outlet Temperature  | North / South   | 35    | 35   |
| Cooling Water Heat Exchanger Discharge Pressure  | North / South   | 14    | 14   |
| Air In-leakage @ 2A / 2B Vacuum Pumps  |                 | -     | -    |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   |                 | -     | -    |
| 2B DA Pump Discharge Pressure  |                 |       | -    |
| 2B DA Pump Bearing Lube Oil Pressure   |                 |       | 3.2  |
| 2A DA Pump Discharge Pressure  |                 |       | -    |
| 2A DA Pump Bearing Lube Oil Pressure   |                 |       | 4.5  |
| MBFP/SUBFP Gland Water Pressure  |                 |       | 1.50 |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  |                 | 10    | 130  |
| Coupling Oil Temperature   |                 |       | 100  |
| Turbine Oil Temperature  |                 |       | 85   |
| Turbine Oil Vapor Extractor Vacuum "H2O  |                 |       | 2    |
| Condenser Inlet Temperature  |                 |       | 38   |
| Condenser Outlet Temperature East / West   |                 | 36    | 38   |
| Condenser Inlet Pressure East / West   |                 | 4.5   | 4.5  |
| Air Side/Gas Side Seal Oil Temperature   |                 | 70    | 65   |
| Hydrogen Dew Point / Hydrogen Purity   |                 | -98.2 | 98.4 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  |                 | 53.6  | 0    |
| Flyash Blower Pressure North/South   |                 | -     | -    |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   |                 |       | All  |
| Supplemental Precip Flyash Blower Discharge Pressure   |                 |       | -    |
| Supplemental Precip Flyash Hoppers in Bypass   |                 |       | All  |
| Kaydon System Pressure / Water Meter Reading   |                 |       | 1    |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. |                 |       |      |
| TA-6040 Discharge pressure/Oil temperature   |                 | 2     | 107  |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 45       |          |           |          |          |        |
| T24 | -        |          |           |          |          |        |
| ST2 |          |          |           |          |          |        |
| RT2 | X1- 20   | 19       | -         | 1        | 1400     |        |
|     | X2- 20   |          |           |          |          |        |
| MT2 |          |          |           |          |          |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |      |
|---|---|----|------|
| Circulators in operation  | 2A  | 2B | Both |
| Screen house Recirc valve position  |   |    | %    |
| Forebay Frozen?   | YES   | NO |      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |    |      |

Date: 12-20-24

Shift: N

Name: PETIPAS

Unit 2

|  |             |
|--|-------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | A 1 64      |
| Heat Exchanger Parallel Operation North and South  |             |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 75 / 75     |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 60 / 70     |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55 / 52     |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 0.55 / 0.55 |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 58 / 55     |
| 2B DA Pump Discharge Pressure  | 37.5        |
| 2B DA Pump Bearing Lube Oil Pressure   | 4.5         |
| 2A DA Pump Discharge Pressure  | 42.5        |
| 2A DA Pump Bearing Lube Oil Pressure   | 2.5         |
| MBFP/SUBFP Gland Water Pressure  | 27.5        |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 / 120    |
| Coupling Oil Temperature   | 110         |
| Turbine Oil Temperature  | 105         |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 3.5         |
| Condenser Inlet Temperature  | 38          |
| Condenser Outlet Temperature East / West   | 52 / 50     |
| Condenser Inlet Pressure East / West   | 10 / 11     |
| Air Side/Gas Side Seal Oil Temperature   | 110 / 115   |
| Hydrogen Dew Point / Hydrogen Purity   | -101 / 99.3 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 81 / 60.8   |
| Flyash Blower Pressure North/South   | 2.8 / 3.2   |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 4.5, 6      |
| Supplemental Precip Flyash Blower Discharge Pressure   | 6           |
| Supplemental Precip Flyash Hoppers in Bypass   | 0           |
| Kaydon System Pressure / Water Meter Reading   | 0 / 14260   |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓           |
| TA-6040 Discharge pressure/Oil temperature   | 1           |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 55       |          |           |          |          |        |
| T24 | 64       |          |           |          |          |        |
| ST2 | 35       | 35       | -         | 0        |          |        |
| RT2 | X1- 45   | 38       | -         | 1        | 1600     |        |
|     | X2- 45   |          |           |          |          |        |
| MT2 | 60       | 60       | 25        | 3.5      | 800      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   |  | River Info  |    |      |
|---|--|---|----|------|
|   |  | 2A  | 2B | Both |
| Circulators in operation  |  |   |    |      |
| Screen house Recirc valve position  |  |   |    | % 0  |
| Forebay Frozen?   |  | YES   | NO |      |
| Is there evidence of Deicing water being released to river?   |  | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |  |   |    |      |



Date: 12-20-84

Shift: \_\_\_\_\_

Name: \_\_\_\_\_

Unit 2

|  |      |                    |
|--|------|--------------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65   | 12A                |
| Heat Exchanger Parallel Operation North and South  |      |                    |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 75   | 175                |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 60   | 170                |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55   | 155                |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 15   | 115                |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 58   | 155                |
| 2B DA Pump Discharge Pressure  |      | 375                |
| 2B DA Pump Bearing Lube Oil Pressure   |      | 4                  |
| 2A DA Pump Discharge Pressure  |      | <del>425</del> 425 |
| 2A DA Pump Bearing Lube Oil Pressure   |      | OKAT 2.5           |
| MBFP/SUBFP Gland Water Pressure  |      | 275                |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10   | 1160               |
| Coupling Oil Temperature   |      | 110                |
| Turbine Oil Temperature  |      | 105                |
| Turbine Oil Vapor Extractor Vacuum "H2O  |      | 3 1/2"             |
| Condenser Inlet Temperature  |      | 35                 |
| Condenser Outlet Temperature East / West   | 52   | 150                |
| Condenser Inlet Pressure East / West   | 5    | 15                 |
| Air Side/Gas Side Seal Oil Temperature   | 110  | 110                |
| Hydrogen Dew Point / Hydrogen Purity   | -101 | 199.3              |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.7 | 179.6              |
| Flyash Blower Pressure North/South   |      | 1                  |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   |      |                    |
| Supplemental Precip Flyash Blower Discharge Pressure   |      |                    |
| Supplemental Precip Flyash Hoppers in Bypass   |      |                    |
| Kaydon System Pressure / Water Meter Reading   | 0    | 14200              |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. |      | ✓                  |
| TA-6040 Discharge pressure/Oil temperature   |      | 1                  |

TRANSFORMERS

|     | WDG TEMP         | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|------------------|----------|-----------|----------|----------|--------|
| 2TX | 55               |          |           |          |          |        |
| T24 |                  |          |           |          |          |        |
| ST2 | 35               | 35       | -         | 0        |          |        |
| RT2 | X1- 45<br>X2- 45 | 38       | -         | 1        | 1600     |        |
| MT2 | 60               | 60       | +         | 3 1/2    | 500      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info  |    |      |
|---|---|----|------|
|   | 2A  | 2B |      |
| Circulators in operation                                    |   |    | Both |
| Screen house Recirc valve position                          |   | 0  | %    |
| Forebay Frozen?   | YES   | NO |      |
| Is there evidence of Deicing water being released to river? | If YES close off on the Screen house Recirc valve until there is no flow. |    | NO   |

NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service.

Date: 2/21/24

Shift: DAY

Name: Perlita Chavez

Unit 2

|  |               |
|--|---------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 05   2A       |
| Heat Exchanger Parallel Operation North and South  |               |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 74   72       |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 60   70       |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 60   55       |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 12   15       |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 56   56       |
| 2B DA Pump Discharge Pressure  | 475           |
| 2B DA Pump Bearing Lube Oil Pressure   | 4.5           |
| 2A DA Pump Discharge Pressure  | 120           |
| 2A DA Pump Bearing Lube Oil Pressure   | 2.5           |
| MBFP/SUBFP Gland Water Pressure  | 260           |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10   169      |
| Coupling Oil Temperature   | 110           |
| Turbine Oil Temperature  | 105           |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 3.0           |
| Condenser Inlet Temperature  | 98            |
| Condenser Outlet Temperature East / West   | 54   52       |
| Condenser Inlet Pressure East / West   | 5   5         |
| Air Side/Gas Side Seal Oil Temperature   | 110   110     |
| Hydrogen Dew Point / Hydrogen Purity   | -67.21   99.2 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 61.4   82.0   |
| Flyash Blower Pressure North/South   | 0.4   5.0     |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | NO            |
| Supplemental Precip Flyash Blower Discharge Pressure   | 4.1           |
| Supplemental Precip Flyash Hoppers in Bypass   | NO            |
| Kaydon System Pressure / Water Meter Reading   | 0   1428.1    |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | YES           |
| TA-6040 Discharge pressure/Oil temperature   | 253   117     |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 054      |          |           |          |          |        |
| T24 | 8.0      |          |           |          |          |        |
| ST2 | 3.3      | 35       | 75        | 0        |          |        |
| RT2 | X1- 42   | 38       | 25        | 1        | 1700     | 0      |
|     | X2- 42   |          |           |          |          |        |
| MT2 | 65       | 65       | 28        | 3.5      | 550      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |  |         |
|---|--|---------|
| Circulators in operation  | 2A   | 2B Both |
| Screen house Recirc valve position  |  | 0 %     |
| Forebay Frozen?   | YES  | NO      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. NO |         |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |  |         |

Date: 22DEC24

Shift: D

Name: Rowell

Unit 2

|  |            |       |
|--|------------|-------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 60         | 12A   |
| Heat Exchanger Parallel Operation North and South  |            |       |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 80         | 180   |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 80         | 180   |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55         | 155   |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 15         | 119   |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 60         | 145   |
| 2B DA Pump Discharge Pressure  | 400        |       |
| 2B DA Pump Bearing Lube Oil Pressure   | 4          |       |
| 2A DA Pump Discharge Pressure  | 400        |       |
| 2A DA Pump Bearing Lube Oil Pressure   | 2.5        |       |
| MBFP/SUBFP Gland Water Pressure  | 275        |       |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10         | 1150  |
| Coupling Oil Temperature   | 115        |       |
| Turbine Oil Temperature  | 110        |       |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 3          |       |
| Condenser Inlet Temperature  | 40         |       |
| Condenser Outlet Temperature East / West   | 80         | 180   |
| Condenser Inlet Pressure East / West   | 3          | 13    |
| Air Side/Gas Side Seal Oil Temperature   | 112        | 112   |
| Hydrogen Dew Point / Hydrogen Purity   | -117       | 199.6 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 62         | 184.3 |
| Flyash Blower Pressure North/South   | 5          | 14.5  |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 3,4,5,7,10 |       |
| Supplemental Precip Flyash Blower Discharge Pressure   | 4.2        |       |
| Supplemental Precip Flyash Hoppers in Bypass   | 0          |       |
| Kaydon System Pressure / Water Meter Reading   |            | 1     |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. |            | ✓     |
| TA-6040 Discharge pressure/Oil temperature   | 258        | 118   |
| #45 SUPPLEMENTAL IN ALARM  |            |       |

TRANSFORMERS

|     | WDG TEMP   | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|------------|----------|-----------|----------|----------|--------|
| 2TX | 48         |          |           |          |          |        |
| T24 | NO READING |          |           |          |          |        |
| ST2 | 35         | 35       | —         | -1       |          |        |
| RT2 | X1- 40     | 30       | —         | -1       | 1500     |        |
|     | X2- 40     |          |           |          |          |        |
| MT2 | 60         | 70       | +         | 3        | 560      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   |   | River Info |      |      |
|---|---|------------|------|------|
| Circulators in operation  | 2A  |            | 2B   | Both |
| Screen house Recirc valve position  |   |            | 35 % |      |
| Forebay Frozen?   | YES   |            | NO   |      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |            |      | NO   |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |            |      |      |



Date: 12-23-24

Shift: D

Name: AP

Unit 2

|  |            |
|--|------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 2A 1 62    |
| Heat Exchanger Parallel Operation North and South  |            |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 76 177     |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 66 168     |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 50 155     |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 12 15      |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 55 158     |
| 2B DA Pump Discharge Pressure  | 350        |
| 2B DA Pump Bearing Lube Oil Pressure   | 4.5        |
| 2A DA Pump Discharge Pressure  | 375        |
| 2A DA Pump Bearing Lube Oil Pressure   | 2.5        |
| MBFP/SUBFP Gland Water Pressure  | 250        |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 170     |
| Coupling Oil Temperature   | 110        |
| Turbine Oil Temperature  | 110        |
| Turbine Oil Vapor Extractor Vacuum "H20  | 3          |
| Condenser Inlet Temperature  | 42         |
| Condenser Outlet Temperature East / West   | 91 193     |
| Condenser Inlet Pressure East / West   | 3.5 13.5   |
| Air Side/Gas Side Seal Oil Temperature   | 105 105    |
| Hydrogen Dew Point / Hydrogen Purity   | -109 198.9 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.9 182.8 |
| Flyash Blower Pressure North/South   | 4.4 14.6   |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 3.2, 9, 10 |
| Supplemental Precip Flyash Blower Discharge Pressure   | 3.2        |
| Supplemental Precip Flyash Hoppers in Bypass   |            |
| Kaydon System Pressure / Water Meter Reading   | 0 14281    |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | OK         |
| TA-6040 Discharge pressure/Oil temperature   | 254 115    |

TRANSFORMERS

|     | WDG TEMP         | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|------------------|----------|-----------|----------|----------|--------|
| 2TX | 45               |          |           |          |          |        |
| T24 |                  |          |           |          |          |        |
| ST2 | 35               | 30       |           | 0        |          |        |
| RT2 | X1- 40<br>X2- 40 | 35       |           | 1        | 1500     |        |
| MT2 | 65               | 60       | +         | 3        | 500      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   | River Info   |         |
|---|--|---------|
| Circulators in operation  | 2A   | 2B Both |
| Screen house Recirc valve position  | 30   | %       |
| Forebay Frozen?   | YES  | NO      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. NO |         |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |  |         |



Date: 12/23/24

Shift: Night

Name: 12/23/24  
Peri Chavez

Unit 2

|  |                    |
|--|--------------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 64 / 2A            |
| Heat Exchanger Parallel Operation North and South  |                    |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 76 / 78            |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 65 / 68            |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55 / 52            |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 14 / 13            |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | <del>58</del> / 60 |
| 2B DA Pump Discharge Pressure  | 480                |
| 2B DA Pump Bearing Lube Oil Pressure   | 4.5                |
| 2A DA Pump Discharge Pressure  | 110                |
| 2A DA Pump Bearing Lube Oil Pressure   | 2                  |
| MBFP/SUBFP Gland Water Pressure  | 250                |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 11 / 170           |
| Coupling Oil Temperature   | 110                |
| Turbine Oil Temperature  | 110                |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2.9                |
| Condenser Inlet Temperature  | 40                 |
| Condenser Outlet Temperature East / West   | 84 / 88            |
| Condenser Inlet Pressure East / West   | 4 / 4              |
| Air Side/Gas Side Seal Oil Temperature   | 108 / 110          |
| Hydrogen Dew Point / Hydrogen Purity   | -92.8 / 95.9       |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 20 / 83.2          |
| Flyash Blower Pressure North/South   | 5.6 / 5.1          |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | NO                 |
| Supplemental Precip Flyash Blower Discharge Pressure   | 5.7                |
| Supplemental Precip Flyash Hoppers in Bypass   | NO                 |
| Kaydon System Pressure / Water Meter Reading   | 0 / 428.1          |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | Yes                |
| TA-6040 Discharge pressure/Oil temperature   | 244.1 / 115        |
|  | 244.1 / 115        |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 51       |          |           |          |          |        |
| T24 | 80       |          |           |          |          |        |
| ST2 | 40       | 33       | 26        | 0        |          |        |
| RT2 | X1- 42   | 38       | 25        | 2        | 1600     | 0      |
|     | X2- 43   |          |           |          |          |        |
| MT2 | 60       | 43       | 27        | 3        | 300      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |   |         |
|---|---|---------|
| Circulators in operation  | 2A  | 2B Both |
| Screen house Recirc valve position  |   | 25 %    |
| Forebay Frozen?   | YES   | NO      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |         |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |         |

Date: 12-24-04 Shift: D Name: MB

Unit 2

|  |             |
|--|-------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 65 / 2A     |
| Heat Exchanger Parallel Operation North and South  |             |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 72 / 72     |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 62 / 62     |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 55 / 55     |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 1           |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 55 / 55     |
| 2B DA Pump Discharge Pressure  | 350         |
| 2B DA Pump Bearing Lube Oil Pressure   | 4.5         |
| 2A DA Pump Discharge Pressure  | 400         |
| 2A DA Pump Bearing Lube Oil Pressure   | 3           |
| MBFP/SUBFP Gland Water Pressure  | 250         |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 / 170    |
| Coupling Oil Temperature   | 110         |
| Turbine Oil Temperature  | 110         |
| Turbine Oil Vapor Extractor Vacuum "H20  |             |
| Condenser Inlet Temperature  | 40          |
| Condenser Outlet Temperature East / West   | 85 / 90     |
| Condenser Inlet Pressure East / West   | 4 / 4       |
| Air Side/Gas Side Seal Oil Temperature   | 110 / 110   |
| Hydrogen Dew Point / Hydrogen Purity   | -71 / 98.8  |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 61.3 / 84.9 |
| Flyash Blower Pressure North/South   | 6 / 5.5     |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   |             |
| Supplemental Precip Flyash Blower Discharge Pressure   | 5           |
| Supplemental Precip Flyash Hoppers in Bypass   | —           |
| Kaydon System Pressure / Water Meter Reading   | 25 / 4280   |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓           |
| TA-6040 Discharge pressure/Oil temperature   | 1           |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX |          |          |           |          |          |        |
| T24 |          |          |           |          |          |        |
| ST2 | 40       | 40       | 25-       | 1        |          |        |
| RT2 | X1- 50   | 40       | 25-       | 2        | 1600     | —      |
|     | X2- 50   |          |           |          |          |        |
| MT2 | 60       | 70       | 254       | 4        | 500      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |  |           |
|---|--|-----------|
| Circulators in operation  | 2A   | (2B) Both |
| Screen house Recirc valve position  |  | 30%       |
| Forebay Frozen?   | YES  | (NO)      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. (NO) |           |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |  |           |

Date: 12/24/24

Shift: N

Name: Rowell

Unit 2

|  |                              |
|--|------------------------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 83 129                       |
| Heat Exchanger Parallel Operation North and South  |                              |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 72 172                       |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 62 163                       |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 50 152                       |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 10 110                       |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 62 163                       |
| 2B DA Pump Discharge Pressure  | 350                          |
| 2B DA Pump Bearing Lube Oil Pressure   | 4.5                          |
| 2A DA Pump Discharge Pressure  | 400                          |
| 2A DA Pump Bearing Lube Oil Pressure   | 3                            |
| MBFP/SUBFP Gland Water Pressure  | 260                          |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 16 1120                      |
| Coupling Oil Temperature   | 110                          |
| Turbine Oil Temperature  | 110                          |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 3                            |
| Condenser Inlet Temperature  | 40                           |
| Condenser Outlet Temperature East / West   | 82 190                       |
| Condenser Inlet Pressure East / West   | 3 14                         |
| Air Side/Gas Side Seal Oil Temperature   | 109 111                      |
| Hydrogen Dew Point / Hydrogen Purity   | -69.5 198.7                  |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.8 183.9                   |
| Flyash Blower Pressure North/South   | 4.8 14.7                     |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | <del>3, 6, 7, 8, 9, 10</del> |
| Supplemental Precip Flyash Blower Discharge Pressure   | 4.4                          |
| Supplemental Precip Flyash Hoppers in Bypass   |                              |
| Kaydon System Pressure / Water Meter Reading   | 0 14280                      |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓                            |
| TA-6040 Discharge pressure/Oil temperature   | 242 116                      |

TRANSFORMERS

|     | WDG TEMP              | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|-----------------------|----------|-----------|----------|----------|--------|
| 2TX | <del>NO DISPLAY</del> |          |           |          |          |        |
| T24 | NO DISPLAY            |          |           |          |          |        |
| ST2 | 35                    | 35       | +         | 1.0      |          |        |
| RT2 | X1- 45                | 40       | +         | 1.5      | 1600     |        |
|     | X2- 45                |          |           |          |          |        |
| MT2 | 60                    | 85       | +         | 3.5      | 500      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |   |      |
|---|---|------|
| Circulators in operation  | 2A  | 2B   |
| Screen house Recirc valve position  |   | 25 % |
| Forebay Frozen?   | YES   | NO   |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |      |
|   | (NO)  |      |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |      |



Date: 12/25/24

Shift: Night

Name: Reil Chavez

Unit 2

|  |                                     |
|--|-------------------------------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 2A / 64                             |
| Heat Exchanger Parallel Operation North and South  |                                     |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 72 / 72                             |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 60 / 62                             |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 50 / 52                             |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 15 / 20                             |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 52 / 58                             |
| 2B DA Pump Discharge Pressure  | 480                                 |
| 2B DA Pump Bearing Lube Oil Pressure   | 4.5                                 |
| 2A DA Pump Discharge Pressure  | 140                                 |
| 2A DA Pump Bearing Lube Oil Pressure   | 3                                   |
| MBFP/SUBFP Gland Water Pressure  | 300                                 |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 11 / 168                            |
| Coupling Oil Temperature   | 105                                 |
| Turbine Oil Temperature  | 110                                 |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2-8                                 |
| Condenser Inlet Temperature  | 58 <del>70</del> / <del>78</del> 40 |
| Condenser Outlet Temperature East / West   | 70 <del>72</del> / 78               |
| Condenser Inlet Pressure East / West   | 4.51 / 4.5                          |
| Air Side/Gas Side Seal Oil Temperature   | 100 / 110                           |
| Hydrogen Dew Point / Hydrogen Purity   | 83.1 / 98.6                         |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.6 / 85.7                         |
| Flyash Blower Pressure North/South   | 4.41 / 9.7                          |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | <del>NO</del> 3, 7, 9, 10           |
| Supplemental Precip Flyash Blower Discharge Pressure   | 4.1                                 |
| Supplemental Precip Flyash Hoppers in Bypass   | <del>NO</del> 4                     |
| Kaydon System Pressure / Water Meter Reading   | 1 / 14280.1                         |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | YES                                 |
| TA-6040 Discharge pressure/Oil temperature   | 250 / 116                           |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 50       |          |           |          |          |        |
| T24 | 008      |          |           |          |          |        |
| ST2 | 40       | 78       | 25        | 0        |          |        |
| RT2 | X1- 40   | 78       | 25        | 3        | 1500     | 0      |
|     | X2- 40   |          |           |          |          |        |
| MT2 | 60       | 60       | 30        | 3        | 500      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |   |         |
|---|---|---------|
| Circulators in operation  | 2A  | 2B Both |
| Screen house Recirc valve position  |   | 30 %    |
| Forebay Frozen?   | YES   | NO      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |         |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |         |



Date: 12-25-24

Shift: D

Name: AP

Unit 2

|  |             |
|--|-------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 63 1 2A     |
| Heat Exchanger Parallel Operation North and South  |             |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 70 1 72     |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 60 1 62     |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 50 1 54     |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 7 1 7       |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 58 1 54     |
| 2B DA Pump Discharge Pressure  | 460         |
| 2B DA Pump Bearing Lube Oil Pressure   | 4.5         |
| 2A DA Pump Discharge Pressure  | 450         |
| 2A DA Pump Bearing Lube Oil Pressure   | 2.5         |
| MBFP/SUBFP Gland Water Pressure  | 300         |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 16 1 170    |
| Coupling Oil Temperature   | 110         |
| Turbine Oil Temperature  | 110         |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 2.8         |
| Condenser Inlet Temperature  | 34          |
| Condenser Outlet Temperature East / West   | 76 1 72     |
| Condenser Inlet Pressure East / West   | 4 1 4       |
| Air Side/Gas Side Seal Oil Temperature   | 105 1 105   |
| Hydrogen Dew Point / Hydrogen Purity   | -86.61 98.7 |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.31 85.1  |
| Flyash Blower Pressure North/South   | 4 3 1 4.5   |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 3.7, 4, 10  |
| Supplemental Precip Flyash Blower Discharge Pressure   | 4.2         |
| Supplemental Precip Flyash Hoppers in Bypass   | -           |
| Kaydon System Pressure / Water Meter Reading   | 0 1 4281    |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | OK          |
| TA-6040 Discharge pressure/Oil temperature   | 1           |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX | 49       |          |           |          |          |        |
| T24 | -        |          |           |          |          |        |
| ST2 | 35       | 35       | -         | 0        |          |        |
| RT2 | X1- 40   | 30       | -         | 1.5      | 1500     |        |
|     | X2- 40   |          |           |          |          |        |
| MT2 | 55       | 55       | +         | 3        | 500      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |  |           |
|---|--|-----------|
| Circulators in operation  | 2A   | (2B) Both |
| Screen house Recirc valve position  |  | 20 %      |
| Forebay Frozen?   | YES  | NO        |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. NO |           |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |  |           |

Date: 12/26/

Shift: N

Name: ERIK

Unit 2

|  |              |
|--|--------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 12A          |
| Heat Exchanger Parallel Operation North and South  |              |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 270 152.72   |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 62 182       |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 525 152      |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 10 110       |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 60 180       |
| 2B DA Pump Discharge Pressure  | 408          |
| 2B DA Pump Bearing Lube Oil Pressure   | 3            |
| 2A DA Pump Discharge Pressure  | 430          |
| 2A DA Pump Bearing Lube Oil Pressure   | 3            |
| MBFP/SUBFP Gland Water Pressure  | 258          |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 1170      |
| Coupling Oil Temperature   | 110          |
| Turbine Oil Temperature  | 105          |
| Turbine Oil Vapor Extractor Vacuum "H2O  | 3            |
| Condenser Inlet Temperature  | 38           |
| Condenser Outlet Temperature East / West   | 70 178       |
| Condenser Inlet Pressure East / West   | 4 14         |
| Air Side/Gas Side Seal Oil Temperature   | 108 110      |
| Hydrogen Dew Point / Hydrogen Purity   | -87 198.5    |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.8 186.8   |
| Flyash Blower Pressure North/South   | 4.8 14.9     |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   |              |
| Supplemental Precip Flyash Blower Discharge Pressure   | 4.5          |
| Supplemental Precip Flyash Hoppers in Bypass   | NONE ALARM 4 |
| Kaydon System Pressure / Water Meter Reading   | 0 14250      |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. | ✓            |
| TA-6040 Discharge pressure/Oil temperature   | 201 1115     |

TRANSFORMERS

|     | WDG TEMP   | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|------------|----------|-----------|----------|----------|--------|
| 2TX | 48         |          |           |          |          |        |
| T24 | NO DISPLAY |          |           |          |          |        |
| ST2 | 35         | 35       | —         | 0        |          |        |
| RT2 | X1- 40     | 35       | —         | 1        | 1500     |        |
|     | X2- 40     |          |           |          |          |        |
| MT2 | 55         | 60       | +         | 3        | 900      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

| River Info  |   |         |
|---|---|---------|
| Circulators in operation  | 2A  | 2B Both |
| Screen house Recirc valve position  |   | 30 %    |
| Forebay Frozen?   | YES   | NO      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |         |
|   | NO  |         |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |         |

Date: 12-26-24

Shift: D

Name: MTS

Unit 2

|  |             |
|--|-------------|
| Cooling Water Pump Discharge Pressure / Pumps in service   | 60 12A      |
| Heat Exchanger Parallel Operation North and South  |             |
| Cooling Water Heat Exchanger Inlet Temperature North / South   | 70 170      |
| Cooling Water Heat Exchanger Outlet Temperature North / South  | 60 160      |
| Cooling Water Heat Exchanger Discharge Pressure North / South  | 50 150      |
| Air In-leakage @ 2A / 2B Vacuum Pumps  | 1           |
| Seal Water Temp @ 2A and 2B Vacuum Pumps   | 50 150      |
| 2B DA Pump Discharge Pressure  | 350         |
| 2B DA Pump Bearing Lube Oil Pressure   | 7.5         |
| 2A DA Pump Discharge Pressure  | 450         |
| 2A DA Pump Bearing Lube Oil Pressure   | 3           |
| MBFP/SUBFP Gland Water Pressure  | 300         |
| Coupling Oil Pump Suction Pressure/Discharge Pressure  | 10 170      |
| Coupling Oil Temperature   | 110         |
| Turbine Oil Temperature  | 110         |
| Turbine Oil Vapor Extractor Vacuum "H2O  |             |
| Condenser Inlet Temperature  | 40          |
| Condenser Outlet Temperature East / West   | 70 180      |
| Condenser Inlet Pressure East / West   | 5 15        |
| Air Side/Gas Side Seal Oil Temperature   | 110 110     |
| Hydrogen Dew Point / Hydrogen Purity   | -84 / 98.6  |
| Hydrogen Gas Pressure / Hydrogen Fan Pressure  | 59.6 / 86.2 |
| Flyash Blower Pressure North/South   | 5.4 / 5.8   |
| Precipitator Flyash hoppers in Bypass/Alarms in Bypass   | 3, 7, 9, 10 |
| Supplemental Precip Flyash Blower Discharge Pressure   | 5.4         |
| Supplemental Precip Flyash Hoppers in Bypass   | 4           |
| Kaydon System Pressure / Water Meter Reading   | 1           |
| All slag sluice handling equipment for MK2 has been inspected for proper operation and discrepancies have been reported. |             |
| TA-6040 Discharge pressure/Oil temperature   | 1           |

TRANSFORMERS

|     | WDG TEMP | OIL TEMP | OIL LEVEL | PRESSURE | N2 PRESS | HYDRAN |
|-----|----------|----------|-----------|----------|----------|--------|
| 2TX |          |          |           |          |          |        |
| T24 |          |          |           |          |          |        |
| ST2 | 40       | 40       | 25-       | 1        |          |        |
| RT2 | X1- 50   | 40       | 25-       | 2        | 1100     | —      |
|     | X2- 50   |          |           |          |          |        |
| MT2 | 60       | 60       | 25+       | 3        | 500      |        |

Note: When N2 bottle is 300 psi or lower, notify WFO.

|   |   | River Info |      |
|---|---|------------|------|
| Circulators in operation  | 2A  | 2B         | Both |
| Screen house Recirc valve position  |   | 20 %       |      |
| Forebay Frozen?   | YES   | NO         |      |
| Is there evidence of Deicing water being released to river?   | If YES close off on the Screen house Recirc valve until there is no flow. |            | NO   |
| NOTE: If Deicing is in progress the Traveling screens are to be run in continuous with 1 Circulator in service. |   |            |      |

**APPENDIX C**  
**Summary of Preventative Maintenance Performed**  
**Merrimack Station BATW BMP Plan**

| Completed / Status update | Work Order | Description  | Status |
|---------------------------|------------|--|--------|
| 11/18/2023                | 3080       | Repair Leak on MK1 Water Header Behind Slag Tank   | CLOSE  |
| 11/28/2023                | UDN103715  | Replace MK2 Slag Tank Rodder Air Supply Valve  | CLOSE  |
| 12/5/2023                 | 6107       | Rebuild slag tank swiper pistons   | CLOSE  |
| 1/4/2024                  | UDN103603  | Troubleshoot/Replace 100# Air Root Valve to MK1 Slag Tank  | CLOSE  |
| 1/8/2024                  | UDN101235  | Repair MK2 Slag Tank Level Auto Control (during run)   | CLOSE  |
| 1/12/2024                 | 4125       | Replace MK2 Slag Tank Bearing Water Pump   | CLOSE  |
| 2/6/2024                  | 4293       | Repair MK1 Slag Tank Sluice Gate Four Way Valve (leaking air)  | CLOSE  |
| 2/8/2024                  | 3014       | Repair/Replace MK2 Slag Tank North Fill Nozzle Solenoid  | CLOSE  |
| 2/26/2024                 | 4579       | Repair/Replace Actuator on MK2 Slag Tank Rodder  | CLOSE  |
| 3/5/2024                  | 9530       | Repair/Replace MK2 Slag Rodder   | CLOSE  |
| 3/13/2024                 | 10212      | Replace MK2 Slag Tank Goose Neck Blower Belts  | CLOSE  |
| 3/22/2024                 | 10050      | Recharge MK2 Slag Tank PLC Backup Battery  | CLOSE  |
| 3/26/2024                 | 10653      | Inspect/Replace Venturi on MK2 Sluice Line   | CLOSE  |
| 4/12/2024                 | 11758      | Repair/Replace MK2 Slag Sluice Pump Breaker on 2LA (not recharging when inserted)                        | CLOSE  |
| 4/17/2024                 | 10654      | Repair Hole on Southwest Slope Nozzle on MK2 Slag Tank   | CLOSE  |
| 4/17/2024                 | 10657      | Repair Hole in Pipe on 300# Air Line to MK2 Slag Tank  | CLOSE  |
| 4/17/2024                 | 10664      | Repair/Replace MK2 Slag Tank Service Water Pump  | CLOSE  |
| 4/29/2024                 | 11924      | Inspect MK2 Slag Sump Pit  | CLOSE  |
| 5/2/2024                  | 12433      | Replace the Slag Tank Swiper Arm on MK2 North Swiper   | CLOSE  |
| 5/3/2024                  | 12446      | Replace Venturi on MK2 Slag Tank Sluice Line   | CLOSE  |
| 7/2/2024                  | 14672      | Repair Seal on MK2 Slag Tank Gate  | CLOSE  |
| 7/17/2024                 | 14670      | Repair Leak of MK2 Slag Tank View Port (North Neck) Fitting (leaking between 3-way valve and view port)  | CLOSE  |
| 7/28/2024                 | 15415      | Repair Leak on MK2 South Slag Tank Neck Cooling Water Line   | CLOSE  |
| 7/30/2024                 | 14668      | Repair Leak on MK2 Slag Tank View Port Door (NW Corner of Tank)  | CLOSE  |
| 8/20/2024                 | 15420      | Clean/Vacuum MK2 Slag Pit  | CLOSE  |
| 8/22/2024                 | 15095      | Repair Leak on MK2 Slag Crusher South Seal   | CLOSE  |
| 9/18/2024                 | 16369      | Replace MK2 Slag Tank South Swiper Control Button on 1st Upper Level                                     | CLOSE  |
| 10/30/2024                | 2870       | Repair MK2 Slag Tank Gland Water Pump Packing  | CLOSE  |
| 11/2/2024                 | 16370      | Repair/Replace MK2 Slag Tank Level Control Valve   | CLOSE  |
| 11/21/2024                | 14429      | Annual Inspection of MK2 Slag Tank for Proper Operation; Inspect and Adjust Chain and Check Segment      | CLOSE  |
| 11/25/2024                | 19413      | Repair/Repace MK2 Slag Tank Fill Pump Recirc   | CLOSE  |
| 11/27/2024                | 19412      | Repair MK2 Slag Tank Sluice Gate Fail to Open Alarm (stays in, does not reset/clear, prox sensor issue?) | CLOSE  |
| 11/27/2024                | 19442      | Repair Leak in MK2 Sluice Line at Elbow (just inside trench)   | CLOSE  |
| 12/10/2024                | 19424      | Repair MK2 Slag Tank Low Level Alarm (does not reset/clear when level is normal)                         | CLOSE  |
| 1/31/2025                 | 19407      | Repair Leak on MK2 Slag Tank East Port on North Neck   | CLOSE  |
| 1/31/2025                 | 19408      | Repair Leak on MK2 Slag Tank 2nd Level NW Angled Sight Glass   | CLOSE  |



**Appendix D**  
**Weekly Flow Measurements**

**APPENDIX D**  
**Weekly Flow Measurements**  
**Merrimack Station BATW BMP Plan**

| Week Start Date | Week End Date | Number of Days with MK Unit(s) Operating | MK1 BATW Slag Sluice (gallons) | MK2 BATW Slag Sluice (gallons) | Total BATW Discharged (gallons) | BATW Recycled to the FGD Adsorber (gallons) |
|-----------------|---------------|--|--------------------------------|--------------------------------|---------------------------------|---|
| 1/14/2024       | 1/20/2024     | 6  | 8,010,000                      | 11,860,000                     | 16,750,000                      | 1,486,662                                   |
| 1/21/2024       | 1/27/2024     | 2  | 2,580,000                      | 3,940,000                      | 7,670,000                       | 163,710                                     |
| 3/3/2024        | 3/9/2024      | 2  | -                              | 1,160,000                      | 2,580,000                       | 480   |
| 3/10/2024       | 3/16/2024     | 4  | -                              | 6,590,000                      | 19,990,000                      | 244,250                                     |
| 3/24/2024       | 3/30/2024     | 3  | -                              | 5,670,000                      | 8,520,000                       | 497,190                                     |
| 6/23/2024       | 6/29/2024     | 1  | -                              | 610,000                        | 420,000                         | 28,270                                      |
| 6/30/2024       | 7/6/2024      | 1  | -                              | 720,000                        | 220,000                         | 13,520                                      |
| 7/7/2024        | 7/13/2024     | 6  | -                              | 14,820,000                     | 15,300,000                      | 2,265,390                                   |
| 7/14/2024       | 7/20/2024     | 6  | -                              | 14,680,000                     | 18,840,000                      | 2,062,640                                   |
| 7/28/2024       | 8/3/2024      | 3  | -                              | 7,700,000                      | 4,350,000                       | 470,970                                     |
| 8/4/2024        | 8/10/2024     | 4  | -                              | 8,340,000                      | 14,050,000                      | 1,140,920                                   |
| 11/10/2024      | 11/16/2024    | 1  | -                              | 630,000                        | 660,000                         | 6,300                                       |
| 11/17/2024      | 11/23/2024    | 3  | -                              | 3,810,000                      | 3,790,000                       | 34,910                                      |
| 11/24/2024      | 11/30/2024    | 5  | -                              | 12,920,000                     | 12,890,000                      | 1,797,920                                   |
| 12/1/2024       | 12/7/2024     | 7  | -                              | 18,480,000                     | 19,140,000                      | 3,663,840                                   |
| 12/8/2024       | 12/14/2024    | 1  | -                              | 2,640,000                      | 2,420,000                       | 160,320                                     |
| 12/15/2024      | 12/21/2024    | 4  | -                              | 9,090,000                      | 13,370,000                      | 1,432,200                                   |
| 12/22/2024      | 12/28/2024    | 7  | -                              | 17,860,000                     | 26,140,000                      | 3,212,430                                   |

**Annual Average Recycle Flow for Days when MK Unit(s) Operated (GPD)** 283,059

Notes:

The weekly volumes are the total volume measured that week on days when one or both MK units were operated.

Only those weeks in which one or both MK units were operated are included. No BATW flows occurred in other weeks.

The annual average recycle flow was calculated by taking the total recycle volume and dividing by the total number of days with BATW generated.